US of Engineers

COMPUTER AIDED STRUCTURAL ENGINEERING (CASE) PROJECT

INSTRUCTION REPORT ITL-92-3

CONCEPT DESIGN EXAMPLE, COMPUTER AIDED STRUCTURAL MODELING (CASM)

Report 1

SCHEME A



by

David Wickersheimer, Gene McDermott, Carl Roth

Wickersheimer Engineers, Inc.
821 South Neil Street
Champaign, Illinois 61820

and

Michael E. Pace

Information Technology Laboratory

DEPARTMENT OF THE ARMY
Waterways Experiment Station, Corps of Engineers
3909 Halls Ferry Road, Vicksburg, Mississippi 39180-6199



June 1992
Report 1 of a Series

Approved For Public Release; Distribution Is Unlimited

Prepared for DEPARTMENT OF THE ARMY
US Army Corps of Engineers
Washington, DC 20314-1000

Under Contract No. DACA39-86-C-0024
(RDT&E Program, Work Unit No. AT40-CA-001)

A

All Steel, Non-Composite,
Lateral Load Resistance = Rigid Frames

Table of Contents
for
Scheme A

Project Description 1
Computer Aided Structural Modeling 7
Criteria 11
City/Installation Database 15
Modeling Philosophy 17
Draw Model 19
Snow Loads 23
Wind Assumptions 29
Main Wind Force Resisting Loads 31
Wind Components & Cladding Loads 37
Dead & Live Loads 41
Minimum Roof Live Load 47
Loads Database 51
Draw Grid & Openings 53
Draw Structure Philosophy 55
Draw Structure 57
Assign Wall Loads Philosophy 67
Assign Loads 69
Analysis & Design Philosophy 77
Surface Element Analysis 79
Steel Roof Dock Design 83
Narrowly Spaced Element Analysis 87
Steel Open-Web Joist Design 95
Widely Spaced Element Analysis: Beam 99
Steel Beam Design 103
Widely Spaced Element Analysis: Girder 107
Steel Beam Design 111
Truss Element Analysis 115
Column Load Run Down 119
Steel Column Design 125
Lateral Resistance Philosophy 129
Define Lateral Resistance 133
Wind Lateral Analysis 137
Seismic Loads 149
Seismic Lateral Analysis 157
Quantity Take-Off Philosophy 167
Quantity Take-Off 169
Concluding Remarks 175

Scheme A


A
B
C
D
E
24.0
24.0
18.0
18.0
8.0
16.0
1
2
3
4
24.0
24.0
24.0
Typical Rigid Frame Locations
Stairs
Joists @ 4' o.c.
Truss
Truss
Lower Roof
Upper Roof
Typical Rigid Frame Locations


Single Ply Adhered Membrane
3" Rigid Insulation
1-1/2" 20 ga Metal Roof Deck
Upper Roof
Mechanical: 3 psf
Electrical: 1 psf
Sprinklers: 2 psf
Lay-In Acoustical Ceiling
10"
Partition Load = 6 psf
5/8" Drywall
3-5/8" Metal Stud
1" Insulation Board
Carpet & Pad
Second Floor
2-1/2" NLWT
2"-20ga Metal Floor Deck
Mechanical: 3 psf
Electrical: 1 psf
Sprinklers: 2 psf
Lay-In Acoustical Ceiling
5" Limestone Panels


Single Ply Membrane
3" Rigid Insulation
1-1/2" 20 ga Metal Roof Deck
+ 1-1/2" Concrete
Lower Roof
Truss
Mechanical: 3 psf
Electrical: 1 psf
Sprinklers: 2 psf

Scheme B







Scheme C


A
B
C
D
24.0
24.0
38.0
A.33
8.0
16.0
1
2
3
4
24.0
24.0
24.0
Truss
Stairs
Joists @ 4' o.c.
Truss
Second Floor
Lower Roof
Upper Roof
Typical 10" Concrete
Shear Walls


Single Ply Adhered Membrane
Upper Roof
4" Concrete Slab
Mechanical: 3 psf
Electrical: 1 psf
Sprinklers: 2 psf
Lay-In Acoustical Ceiling
10"
Partition Load = 6 psf
5/8" Drywall
3-5/8" Metal Stud
1" Insulation Board
Carpet & Pad
Second Floor
4" Concrete Slab
Mechanical: 3 psf
Electrical: 1 psf
Sprinklers: 2 psf
Lay-In Acoustical Ceiling
5" Limestone Panels


Single Ply Membrane
3" Rigid Insulation
1-1/2" 20 ga Metal Roof Deck
+ 1-1/2" Concrete
Lower
Roof
Truss
Mechanical: 3 psf
Electrical: 1 psf
Sprinklers: 2 psf

Project Description



This 1 and 2 story project is to provide approximately 9,500 gross square feet of office space for one of two possible sites:

(a) Charleston, South Carolina

(b) Radford AAP, Virginia

Soil conditions are unknown at both sites.

The following project criteria has been established:

1. The 36' x 72' space on the first level shall be column free for open office planning.

2. The 48' x 72' first and second floor areas shall provide 24' square bays.

3. The first floor shall be a slab on grade with the tops of perimeter continuous wall footings set at 2'-6" below grade. Column footings will be isolated spread footings.

4. The second floor occupancy live loads located on the plan are:

Offices:	50 psf
File Storage:	150 psf
Corridor, Stair & Lobby:	100 psf

5. Structural framing schemes to be designed and compared shall be as follows:

Scheme A: All steel, non-composite,
lateral load resistance = rigid frames.

Scheme B: All steel, composite,
lateral load resistance = X braced frames.

Scheme C: Monolithic concrete for two story portion, steel for lower roof portion,
lateral load resistance = shear walls.

HH

6. The typical exterior envelope consists of 5" limestone panels, 1" rigid insulation, 3-5/8" metal studs, and 5/8" drywall.

7. Window and door openings are uniformly distributed to all elevations.

8. Load Assumptions:

	Importance Category	Exposure Category
Snow:	I	C
Wind:	I	C
Seismic:	IV	

9. Material Assumptions:

Concrete:	4,000 psi, NLWT
	Steel Reinforcing: Grade 60
Steel:	A36

10. Fire resistance rating shall be achieved by a wet sprinkler system.

Computer Aided Structural Modeling




Floor/Roof Framing
Grids & Openings
Draw Structure
One-Way Surface
Linear
Narrowly Spaced
Widely Spaced
Truss
Column
Wall
Assign Loads
Analysis
Simple
Continuous
Pattern Loading
Design
Column/Wall
Load Run Down
Live Load Reduction
Analysis
Design


Lateral Resistance
Wind
Seismic
Seismic Loads
Define Diaphragm
Flexible
Rigid
Define Lateral Resistance
Trussing
Rigid Frame
Shear Wall
Analysis
Quantity Take-Off
Compare Schemes
End
Independant Sub-Programs
Design Loads
Member Self Weight Estimating
2-D Analysis
Member Design Spreadsheets

Criteria


Start
Use Criteria Menu
Project
Project Data
Project Name: Office Building - Scheme A
City/Installation: Radford AAP
Country: USA
State: VA
County: Pulaski
Design Load: TM 5-809-1 1991
Building Code: BOCA
Seismic Code: TM 5-809-10 1991
Elevation Above Sea Level: 3300 ft
No. Of Stories: 2
Floor Area: 9504 sq ft
Occupancy: Use Group B
Type Const: 3A
Seismic Lateral Load Resistance
N-S System: Blank
E-W System: Blank
City/Installation
Select Radford AAP From List
Regional
Review Regional Data
Wind
Basic Wind Speed: 70.0 mph
Coastal: No
Maximum Wind Speed: 58.0 mph
Wind Direction: SE
Snow
Ground Snow Load: 25.0 psf
Maximum Snow Depth: 15.0 in
Snow Density: 17.3 pcf
Rain
Average Annual Rainfall: 44.0 in
Maximum Rainfall: 4.0 in
Temperature
Maximum temperature: 92 °F
Minimum Temperature: -24 °F
Seismic Zone: 2A: 0.150
Frost Depth: 22 in


Site
Site Specific
Wind
Exposure: C
Importance: I: 1.00
Snow
Exposure: C: 1.00
Importance: I: 1.00
Roof Slippery: No
Thermal Factor: 1.0
Seismic
Importance: IV: 1.00
Soil Factor: S3: 1.5
Soil
Blank
Print
Print Data
☒ Basic Design Criteria
☐ All Other
☒ Print To File
☒ Execute Notepad
Scroll Output
Page Setup
Left Margin: 0.5 in
Right Margin: 0.0 in
Print File
Exit Notepad
End

Basic Design Criteria

Project Data

Project Name	: Office Building - Scheme A
City/Installation	: Radford AAP
Country	: USA
State	: VA
County	: Pulaski
Design Load	: TM 5-809-1 1991
Building Code	: BOCA
Seismic Code	: TM 5-809-10 1991
Elevation above sea level	: 3300 ft.
No. of Stories	: 2
Floor Area	: 9504 sqft.
Occupancy	: Use Group B
Type of Construction	: 3A
Seismic Lateral Load Resistance	
N-S System	:
N-S Rw	: 0
E-W System	:
E-W Rw	: 0

Regional Data

Wind	
Basic Wind Speed	: 70.0 mph
Coastal	: No
Maximum Wind Speed	: 58.0 mph
Wind Direction	: SE
Snow	
Ground Snow Load	: 25.0 psf
Maximum Snow Depth	: 15.0 in.
Snow Density	: 17.3 pcf
Rain	
Average Annual Rainfall	: 44.0 in.
Maximum Rainfall	: 4.0 in.
Temperature	
Maximum Temperature	: 92.0 deg F
Minimum Temperature	: -24.0 deg F
Seismic Zone : 2A	: 0.150
Frost Depth	: 22 in.

Site Specific Data

Wind	
Exposure	: C
Importance : I	: 1.00
Snow	
Exposure : C	: 1.00
Importance : I	: 1.00
Roof Slippery	: No
Thermal Factor	: 1.0
Seismic	
Importance : IV	: 1.00
Soil Factor : S3	: 1.5

Notes

Importance Factor for Snow and Wind:

I All buildings and structures except those listed below.

II Buildings and structures where primary occupancy is one in which more than 300 people congregate in one area.

III Buildings and structures designated as essential facilities, including, but not limited to:

- Hospital and other medical facilities having surgery or emergency treatment areas.
- Fire or rescue and police stations.
- Primary communication facilities and disaster operation centers.
- Power stations and other utilities required in an emergency.
- Structures having critical national defense capabilities.

IV Buildings and structures that represent a low hazard to human life in the event of failure, such as agricultural buildings, certain temporary facilities, and minor storage facilities.

Wind Exposure Category:

Exposure C:

Open terrain with scattered obstructions having heights generally less than 30 ft.

Snow Exposure Category:

Exposure C:

Locations in which snow removal by wind cannot be relied on to reduce roof loads because of terrain, higher structures, or several trees nearby.

* The conditions discussed should be representative of those that are likely to exist during the life of the structure. Roofs that contain several large pieces of mechanical equipment or other obstructions do not qualify for siting category A.

Snow Thermal Factor:

Heated Structure.

* These conditions should be representative of those that are likely to exist during the life of the structure.

Importance Factor for Seismic:

I. Essential Facilities

Hospitals and other medical facilities having surgury and emergency treatment areas.

Fire and police stations.

Tanks or other structures containing, housing or supporting water or other fire-suppression materials or equipment required for the protection of essential or hazardous facilities, or special occupancy structures.

Emergency vehicle shelters and garages.

Structures and equipment in emergency preparedness centers.

Stand-by power generating equipment for essential facilities.

Structures and equipment in communication centers and other facilities required for emergency response.

II. Hazardous Facilities

Structures housing, supporting or containing sufficient quantities of toxic or explosive substances to be dangerous to the safety of the general public if released.

III. Special Occupancy Structure

Covered structures whose primary occupancy is public assembly - capacity more than 300 persons.

Buildings for schools (through secondary) or day-care centers - capacity more than 250 students.

Buildings for colleges or adult education schools - capacity more than 500 students.

Medical facilities with 50 or more resident incapacitated patients, but not included above.

Jails and detention facilities.

All structures with occupancy more than 5000 persons.

Structures and equipment in power generating stations and other public utility facilities not included above, and required for

IV. Standard Occupancy Structure

All Structures having occupancies or functions not listed above.

Seismic Soil Factor:

S3: A soil profile 70 feet or more in depth and containing more than 20 feet of soft to medium stiff clay but not more than 40 feet of soft clay.

The site factor shall be established from properly substantiated geotechnical data. In locations where the soil properties are not known in sufficient detail to determine the soil profile type, soil profile S3 shall be used. Soil profile S4 need not be assumed unless the Building Official determines that soil profile S4 may be present at the site, or in the event that soil profile S4 is established by geotechnical data.

Modeling Philosophy

A. Simplify the geometric model

For buildings with repetitive wings, only one wing needs to be modeled.

Insignificant portions such as chimneys, dormers, and small projections, should not be modeled.



Extra wings are not necessary



Simplified model

B. Make sure planes are in contact

A gap between adjoining shapes will make the surfaces exterior.

Use the Stack options to accurately place adjoining shapes.

C. Do not intersect shapes

When modeling parapet walls, make sure the corners do not intersect.



Incorrect



Correct

D. Verify the model

Use the Tape Measure command, zoom in on a plan, elevation and 3-D views to verify the model.

Draw Model


Start
Use Draw Model Tool Palette
Establish Initial Layout Defaults
Ground Plane
Size: 100' x 100'
Spacing: 20' x 20'
✓ Show Ground Plane
Units
Increment: 4"
Display: ft-in
✓ Snap To Units
Initial Object Size
N-S: 73'8"
E-W: 85'8"
Height: 14'0"
Plane Thickness: 10"
Orientation: N-S
✓ Stack On Ground Plane
Draw Building Volume
Draw First Floor Volume
Position Cube On Ground Plane
Double Click Right Mouse Key To End
Draw Second Floor Volume
✓ Stack On Last Shape
Place Cube On Last Shape
Drag Plane To Correct Dimension
E-W: 49'8"
Draw Gable Roof Volume
Place Prism On Last Shape
✓ Lock N-S & E-W
Drag Edge To Correct Roof Slope
Slope: 5.8 in 12


Draw Building Volume
Draw Gable Roof Volume
Unlock N-S & E-W
Draw Parapet Walls
Initial Object Size
Height: 4'0"
✓ Stack On Plane
Position Vertical Plane On Roof
Initial Object Size
Orientation: E-W
Position Vertical Planes On Roof
Rotate View To Select Both Slice Planes
Slice Both E-W Vertical Planes
Delete 4 Unwanted Sliced Shapes
Remove Gable Roof Volume
Delete Prism Shape
Check Building Volume
Tape Measure
Plan, Elevation And Section
Zoom And Pan
End



Snow Loads


Start
Use Loads And Design Tool Palette
Calculate Snow Loads
Review Criteria
Calculate
View Output
View Section
Print Screen
Printer
View Calculations
Print Data
Snow
All Other
Print To File
Execute Notepad
Scroll Output
Page Setup
Left Margin: 0.5 in
Right Margin: 0.0 in
Print File
Exit Notepad
View Perspective (3D)
Solid Object
Show Loads
None
End

Snow Unbalanced (psf)

Snow Balanced (psf)

Snow Drift (psf)

Snow Sliding (psf)



Snow Combined (psf)





Snow Unbalanced (psf)

Snow Balanced (psf)

Snow Drift (psf)

Snow Sliding (psf)



Snow Combined (psf)



```
Project      : Office Building - Scheme A
Location     : Radford AAP
Design Load : TM 5-809-1 1991
Time         : Sat Jan 25, 1992  5:40 PM

******************** Flat/Lean-To Roof Snow Load Design ********************

Flat Roof Snow Load (Pf)
Pf = 0.7*Ce*Ct*I*Pg
Snow Exposure Category: C
Ce = 1.0
Heated Structure.
Ct = 1.0
Importance Category: I
I  = 1.0
Pg = 25.0 psf
Pf = 17.50 psf
Roof Slope: 0.00 in 12
Theta = 0 deg
Check minimum Pf where theta <= 15 deg
When Pg > 20.0 psf, min Pf = 20*I
Min Pf = 20.00 psf
Since theta < 1/2 in/ft, 5 psf rain-on-snow surcharge applies.
+------------------------+
|     Pf = 25.00 psf     |
+------------------------+

Sloped Roof Snow Load (Ps)
Ps = Cs*Pf
Roof Slippery: No
Cs = 1.00
+------------------------+
|     Ps = 25.00 psf     |
+------------------------+

************************* Drift Snow Load Design *************************

Pg = 25.0 psf
Snow Density = 17.25 pcf
Ps = 20.00 psf (rain-on-snow surcharge not included)
hb = Ps/density
hb = 1.16 ft
Projection Height = 4.00 ft
hc = height-hb
hc = 2.84 ft
hc/hb = 2.45 >= 0.20  Therefore consider drift load.
Importance Category: I
I  = 1.0
Snow Exposure Category: C
Ce = 1.0
Separation = 0.00 ft
lu = 35.17 ft
hd = 0.43*lu^1/3*(Pg+10)^1/4-1.5
hd = 1.93 ft
Width of drift: W = minimum of 4*hd or 4*hc >= 10 ft
w = 4*hd = 7.71 ft
w = 4*hc = 11.36 ft
+------------------------+
|      W = 10.00 ft      |
+------------------------+

hd = hd*(20-s)/20 = 1.93 ft
hd <= hc
Pd = hd*density
+------------------------+
|     Pd = 33.23 psf     |
+------------------------+
```

```
************************** Drift Snow Load Design **************************

Pg = 25.0 psf
Snow Density = 17.25 pcf
Ps = 20.00 psf (rain-on-snow surcharge not included)
hb = Ps/density
hb = 1.16 ft
Projection Height = 4.00 ft
hc = height-hb
hc = 2.84 ft
hc/hb = 2.45 >= 0.20  Therefore consider drift load.
Importance Category: I
I  = 1.0
Snow Exposure Category: C
Ce = 1.0
Separation = 0.00 ft
lu = 72.00 ft
hd = 0.43*lu^1/3*(Pg+10)^1/4-1.5
hd = 2.85 ft
Width of drift: W = minimum of 4*hd or 4*hc >= 10 ft
w = 4*hd = 11.40 ft
w = 4*hc = 11.36 ft
+------------------------+
|      W = 11.36 ft      |
+------------------------+

hd = hd*(20-s)/20 = 2.85 ft
hd > hc, therefore hd = hc = 2.84 ft
Pd = hd*density
+------------------------+
|     Pd = 49.00 psf     |
+------------------------+

************************** Drift Snow Load Design **************************

Pg = 25.0 psf
Snow Density = 17.25 pcf
Ps = 20.00 psf (rain-on-snow surcharge not included)
hb = Ps/density
hb = 1.16 ft
Projection Height = 14.00 ft
hc = height-hb
hc = 12.84 ft
hc/hb = 11.08 >= 0.20  Therefore consider drift load.
Importance Category: I
I  = 1.0
Snow Exposure Category: C
Ce = 1.0
Separation = 0.00 ft
lu = 49.67 ft
hd = 0.43*lu^1/3*(Pg+10)^1/4-1.5
hd = 2.34 ft
Width of drift: W = minimum of 4*hd or 4*hc >= 10 ft
w = 4*hd = 9.38 ft
w = 4*hc = 51.36 ft
+------------------------+
|      W = 10.00 ft      |
+------------------------+

hd = hd*(20-s)/20 = 2.34 ft
hd <= hc
Pd = hd*density
+------------------------+
|     Pd = 40.44 psf     |
+------------------------+
```

Wind Assumptions

Proportions For B/L & h/L

Defaults:	Height Ratio:	0.75
	Plan Ratio:	0.75



Building Height Maximum 60 Feet

Assumed for components and cladding

Main Wind Force Resisting Loads




View Output
Show Loads
GCpi = 0
GCpi Positive
GCpi Negative
B & L Assumptions
none
End

Wind Load: GCpi=0 (psf)



Wind Load: GCpi=0 (psf)



Wind Load: GCpi=0 (psf)





Project : Office Building - Scheme A
Location : Radford AAP
Design Load : TM 5-809-1 1991
Time : Tue Feb 18, 1992 4:16 PM

********** Wind Load - 1 **********

Velocity (mph)	Importance Factor	Exposure	Width Perpend. to Wind (ft)	Length Parallel to Wind (ft)	Roof Type
70.0	1.00	C	36.0	73.7	

Distance to ocean line >= 100 mi. h/d = 0.39 <= 5

********** Main Framing Pressures **********

Parallel to Ridge or Length

Location	z or h (ft)	Gh	Kz	qz (psf)	Cp	External Pressure P (psf) GCpi=0	-0.25	0.25
Windward Wall								
parapet	18.0	1.32	0.84	10.5	0.80	11.1		
level 1	14.0	1.32	0.80	10.0	0.80	10.6	13.1	8.1
level 1	0.0	1.32	0.80	10.0	0.80	10.6	13.1	8.1
Leeward Wall	14.0	1.32	0.80	10.0	-0.30	-4.0	-1.5	-6.5
Side Wall	14.0	1.32	0.80	10.0	-0.70	-9.2	-6.7	-11.7
Roof	14.0	1.32	0.80	10.0	-0.70	-9.2	-6.7	-11.7
Internal	14.0		0.80	10.0		0.0	2.5	2.5

********** Wind Load - 2 **********

Velocity (mph)	Importance Factor	Exposure	Width Perpend. to Wind (ft)	Length Parallel to Wind (ft)	Roof Type
70.0	1.00	C	73.7	49.7	

Distance to ocean line >= 100 mi. h/d = 0.56 <= 5

********** Main Framing Pressures **********

Parallel to Ridge or Length

Location	z or h (ft)	Gh	Kz	qz (psf)	Cp	External Pressure P (psf) GCpi=0	-0.25	0.25
Windward Wall								
level 3	28.0	1.26	0.96	12.0	0.80	12.1	15.1	9.1
level 2 - 3	21.0	1.26	0.88	11.0	0.80	11.1	14.1	8.1
level 1 - 2	7.0	1.26	0.80	10.0	0.80	10.1	13.1	7.1
level 1	0.0	1.26	0.80	10.0	0.80	10.1	13.1	7.1
Leeward Wall	28.0	1.26	0.96	12.0	-0.50	-7.6	-4.6	-10.6
Side Wall	28.0	1.26	0.96	12.0	-0.70	-10.6	-7.6	-13.6
Roof	28.0	1.26	0.96	12.0	-0.70	-10.6	-7.6	-13.6
Internal	28.0		0.96	12.0		0.0	-3.0	3.0

********** Wind Load - 3 **********

Velocity (mph)	Importance Factor	Exposure	Width Perpend. to Wind (ft)	Length Parallel to Wind (ft)	Roof Type
70.0	1.00	C	49.7	73.7	

Distance to ocean line >= 100 mi. h/d = 0.56 <= 5

********** Main Framing Pressures **********

Parallel to Ridge or Length

Location	z or h (ft)	Gh	Kz	qz (psf)	Cp	External Pressure P (psf) GCpi=0	-0.25	0.25
Windward Wall								
level 3	28.0	1.26	0.96	12.0	0.80	12.1	15.1	9.1
level 2 - 3	21.0	1.26	0.88	11.0	0.80	11.1	14.1	8.1
level 1 - 2	7.0	1.26	0.80	10.0	0.80	10.1	13.1	7.1
level 1	0.0	1.26	0.80	10.0	0.80	10.1	13.1	7.1
Leeward Wall	28.0	1.26	0.96	12.0	-0.40	-6.0	-3.0	-9.0
Side Wall	28.0	1.26	0.96	12.0	-0.70	-10.6	-7.6	-13.6
Roof	28.0	1.26	0.96	12.0	-0.70	-10.6	-7.6	-13.6
Internal	28.0		0.96	12.0		0.0	-3.0	3.0

********** Wind Load - 4 **********

Velocity (mph)	Importance Factor	Exposure	Width Perpend. to Wind (ft)	Length Parallel to Wind (ft)	Roof Type
70.0	1.00	C	73.7	36.0	

Distance to ocean line >= 100 mi. h/d = 0.39 <= 5

********** Main Framing Pressures **********

Parallel to Ridge or Length

Location	z or h (ft)	Gh	Kz	qz (psf)	Cp	External Pressure P (psf) GCpi=0	-0.25	0.25
Windward Wall								
parapet	18.0	1.32	0.84	10.5	0.80	11.1		
level 1	14.0	1.32	0.80	10.0	0.80	10.6	13.1	8.1
level 1	0.0	1.32	0.80	10.0	0.80	10.6	13.1	8.1
Leeward Wall	14.0	1.32	0.80	10.0	-0.50	-6.6	-4.1	-9.1
Side Wall	14.0	1.32	0.80	10.0	-0.70	-9.2	-6.7	-11.7
Roof	14.0	1.32	0.80	10.0	-0.70	-9.2	-6.7	-11.7
Internal	14.0		0.80	10.0		0.0	-2.5	2.5

********** Wind Load - 5 **********

Velocity (mph)	Importance Factor	Exposure	Width Perpend. to Wind (ft)	Length Parallel to Wind (ft)	Roof Type
70.0	1.00	C	73.7	49.7	

Distance to ocean line >= 100 mi. h/d = 0.56 <= 5

********** Main Framing Pressures **********

Parallel to Ridge or Length

Location	z or h (ft)	Gh	Kz	qz (psf)	Cp	External Pressure P (psf) GCpi=0	-0.25	0.25
Windward Wall								
level 2	28.0	1.26	0.96	12.0	0.80	12.1	15.1	9.1
level 1 - 2	14.0	1.26	0.80	10.0	0.80	10.1	13.1	7.1
level 1	0.0	1.26	0.80	10.0	0.80	10.1	13.1	7.1
Leeward Wall	28.0	1.26	0.96	12.0	-0.50	-7.6	-4.6	-10.6
Side Wall	28.0	1.26	0.96	12.0	-0.70	-10.6	-7.6	-13.6
Roof	28.0	1.26	0.96	12.0	-0.70	-10.6	-7.6	-13.6
Internal	28.0		0.96	12.0		0.0	-3.0	3.0

Notes for main framing:
Positive pressures act toward surfaces.
Pressure or suction = P = q*Gh*Cp-qh*(GCpi)
q: qz for windward wall evaluated at height z.
qh for leeward wall, side walls, and roof evaluated at mean roof height.

Wind Components & Cladding Loads




View Output
View Calculations
Print Data
☒ Wind
☐ All Other
☒ Print To File
☒ Execute Notepad
Scroll Output
Page Setup
Left Margin: 0.5 in
Right Margin: 0.0 in
Print File
Exit Notepad
View Perspective (3D)
Solid Object
Show Loads
Components & Cladding
Zone Areas
none
End

Wind Load: Components & Cladding (psf)



Wind Load: Components & Cladding (psf)





Project : Office Building - Scheme A
Location : Radford AAP
Design Load : TM 5-809-1 1991
Time : Sat Jan 25, 1992 5:49 PM

********** Wind Load **********

Velocity (mph)	Importance Factor	Exposure	Width Perpend. to Wind (ft)	Length Parallel to Wind (ft)	Roof Type
70.0	1.00	C	49.7	73.7	

Distance to ocean line >= 100 mi. h/d = 0.56 <= 5

Height (ft)	Kh	qh (psf)	GCpi	
28.0	0.96	12.0	-0.25	0.25

Height <= 60 ft

********** Component/Cladding Pressures (psf) **********

	Walls							
	Windward				Leeward			
Tributary Area (sf)	Zone 4 middles		Zone 5 corners		Zone 4 middles		Zone 5 corners	
	GCp	P	GCp	P	GCp	P	GCp	P
Internal		-3.0		-3.0		3.0		3.0
Limestone Panel	4.67 ft x 14.00 ft. **							
65.3	1.21	17.5	1.21	17.5	-1.31	16.7	-1.57	-21.8
a = 5.0 ft								

Notes for components and cladding:
P = qh(GCp)-qh(GCpi)
Internal pressures have been included in above values.
* For roof overhangs: algebraically add this pressure to the above values. P = qh(GCp) = 0.8qh
To comply with TM 5-809-1, wall external pressures have not been reduced 10% per ASCE figure 3, note 3.
** For a rectangular tributary area, the width of the area need not be less than one-third the length of the area.

Dead & Live Loads




Dead Loads
Floor Dead Loads
Save
Stop Using Floor (DL)
Roof Dead Loads
Use Roof (DL)
Input
Name: Lower Roof
Type psf
Roofing: Single Ply 1.5
Deck: MTL DK 1.5/NWT 2.5 36.0
Structure: Steel Bar Jst 24'@4' 1.8
Mechanical: Mech A/C Ducts 3.0
Electrical: Elect/Lighting 1.0
Fire Protection: Sprinklers Wet 2.0
Insulation: Rigid Roof Ins 3" 2.4
Ceiling:
Total: 47.7
Save
Input
Name: Upper Roof
Type psf
Roofing: Single Ply 1.5
Deck: Steel 1-1/2" 20ga 2.5
Structure: Steel Beams 0.0
Mechanical: Mech A/C Ducts 3.0
Electrical: Elect/Lighting 1.0
Fire Protection: Sprinklers Wet 2.0
Insulation: Rigid Roof Ins 3" 2.4
Ceiling: Susp Chnl/Tile 2.0
Total: 14.4
Save
Next To View Lower Roof Load
Stop Using Roof (DL)


Dead Loads
Wall Dead Loads
Use Wall (DL)
Input
Name: Exterior Wall
Type psf
Finish: Limestone 5" 68.8
Sheathing:
Structure: Stl Stud 16ga 4"@16 1.1
Insulation: Exp Polyst Rigid 1" 0.2
Finish: Gypboard 5/8" 3.1
Total: 73.2
Save
Input
Name: Parapet
Type psf
Finish: Limestone 5" 68.8
Sheathing:
Structure:
Insulation:
Finish:
Total: 68.8
Save
Next To View Exterior Wall Load
Stop Using Wall (DL)
Print
Print Data
Loads
All Other
Print To File
Execute Notepad


Print
Scroll Output
Page Setup
Left Margin: 0.5 in
Right Margin: 0.0 in
Print File
Exit Notepad
End

Loads

Floor Dead Loads

Name	: Second Floor	
	Type	psf
Partition	: 51-100 plf	6.0
Finish	: Carpet & Pad	1.0
Deck	: MTL DK 2.0/NLWT 2.5	42.0
Structure	: Steel Beams	0.0
Mechanical	: Mech A/C Ducts	3.0
Electrical	: Elect/Lighting	1.0
Fire Protection	: Sprinklers Wet	2.0
Ceiling	: Susp Chnl/Tile	2.0
Total	:	57.0

Roof Dead Loads

Name	: Lower Roof	
	Type	psf
Roofing	: Single Ply	1.5
Deck	: MTL DK 1.5/NLWT 2.5	36.0
Structure	: Steel Bar Jst 24'@4'	1.8
Mechanical	: Mech A/C Ducts	3.0
Electrical	: Elect/Lighting	1.0
Fire Protection	: Sprinklers Wet	2.0
Insulation	: Rigid Roof Ins 3"	2.4
Ceiling	:	0.0
Total	:	47.7

Name	: Upper Roof	
	Type	psf
Roofing	: Single Ply	1.5
Deck	: Steel 1-1/2" 20ga	2.5
Structure	: Steel Beams	0.0
Mechanical	: Mech A/C Ducts	3.0
Electrical	: Elect/Lighting	1.0
Fire Protection	: Sprinklers Wet	2.0
Insulation	: Rigid Roof Ins 3"	2.4
Ceiling	: Susp Chnl/Tile	2.0
Total	:	14.4

Wall Dead Loads

Name	: Exterior Wall	
	Type	psf
Finish	: Limestone 5"	68.8
Sheathing	:	0.0
Structure	: Stl Stud 16ga 4"@16	1.1
Insulation	: Exp Polysty Rigid 1"	0.2
Finish	: Gypboard 5/8"	3.1
Total	:	73.2

Name	: Parapet	
	Type	psf
Finish	: Limestone 5"	68.8
Sheathing	:	0.0
Structure	:	0.0
Insulation	:	0.0
Finish	:	0.0
Total	:	68.8

Occupancy Live Loads

Name	psf
Office: Offices	50
Office: Corridor (main)	100
Office: Files & Storage	150a

a. Variable design load. Increase may be necessary.

Notes

Uniformly distributed live loads for supporting members; i.e., two-way slab, beam, girder or columns having an influence area of 400 sq ft or more may be reduced with: L = Lo*[0.25+(15/sqrt(Ai))]
The reduced design live load will not be less than 50% of the unit live load for members supporting one floor, nor less than 40% of the unit live load for members supporting two or more floors.
Exceptions: For live loads less than 100 psf, no reduction is permitted for members supporting floor(s) in the following areas:
-public assembly
-garages (except where 2 or more floors are supported)
-one-way slab floor
For live loads greater than 100 psf and for garages used for passenger cars only, no reduction is permitted for members supporting one floor; however, where two or more floors are supported, a 20% reduction is permitted.

Minimum Roof Live Load

Start

Use Loads & Design Tool Palette

Select Second Floor/ Lower Roof Horizontal Structural Plane

Calculate Minimum Roof Live Load

Minimum Roof (LL)

☐ Add Opposite Roof

Tributary Area

	Horizontal	Vertical
Base Point:	62'10"	24'10"
Point 2:	66'10"	48'10"
Length:	4'0"	24'0"

Cancel Minimum Roof (LL)



View Output

View Section

Print Screen

◉ Printer

View Calculations

Print Data

☒ Min. Roof LL
☐ All Other
☒ Print To File
☒ Execute Notepad

Scroll Output

Page Setup

Left Margin: 0.5 in
Right Margin: 0.0 in


View Output
View Calculations
Print File
Exit Notepad
View Perspective (3D)
Solid Object
Show Loads
None
End

```
Project      : Office Building - Scheme A
Location     : Radford AAP
Design Load : TM 5-809-1 1991
Time         : Sat Jan 25, 1992  6:16 PM

********** Minimum Roof Live Load (Lr) **********

Tributary area (At) : 96 sf
Roof slope     (F)  : 0.00 in 12

Lr = 20*R1*R2 >= 12
At <= 200        R1 = 1.00
F <= 4           R2 = 1.00
Lr = 20.00 psf
minimum Lr = 12 psf
+------------------------+
|     Lr = 20.00 psf     |
+------------------------+
Check minimum roof live load, Lr, against minimum snow design loads.

Additionally, for the design of secondary members such as roof
decking and rafters, a concentrated live load with 250 lbs uniformly
distributed over an area of 2 feet square (4 sqft) will be included.
The concentrated load will be located so as to produce the maximum
stress in the member.
```

Loads Database



Draw Grid & Openings




Draw Openings
Add Opening
Horizontal Vertical
Base Point: 10" 24'10"
Point 2: 8'10" 48'10"
Length: 8'0" 24'0"
F2 Key For Keyboard Input
Opening
Name: Stairs
Continuous
End
A
B
C
D
E
1
2
3
4
24.0
18.0
Stairs

Draw Structure Philosophy

Structure Hierarchy

Surface/Deck
(horizontal)



1 way



2 way
(not activated)

Linear
(horizontal)

Narrowly Spaced
(joists)



Widely Spaced
(beams)



Surface
(vertical)
(planar)



Linear
(vertical)



Draw Structure




Draw Upper Roof framing
Draw Surface In Bay A1-B2
Select Handle On Grid Line A1-A2
Select Handle On Grid Line B1-B2
Double Click Right Mouse Key To End Defining Area
Save Surface Element
Orientation: E-W
Copy Beams & One-Way Surface To Other Bays
Copy Structure
Select Third Point Beams
Select One-Way Surface
Double Click Right Mouse Key To End Selecting Structure
Select Grid Location A1 As The Base Point
Paste Structure
Select Grid Locations B1, A2, B2, A3, B3
Double Click Right Mouse Key To End


Draw Upper Roof framing
Draw Columns
Column All Grid Intersections
Save Column Elements
Orientation: N-S
☒ All Floors
Draw Second Floor/ Lower Roof Framing
Select Second Floor/ Lower Roof Horizontal Structural Plane
Draw Linear Beams On All Grid Lines
Delete Beams At Grid Locations Inside C1-E4
Draw Third Point Beams And One-Way Surface In Bays A1-B2, B1-C2, B2-C3, A3-B4, B3-C4
Paste Structure
Select Grid Locations A1, B1, B2, A3, B3
Double Click Right Mouse Key To End
Draw Third Point Beams In Bay A2-B3
Linear: Widely Spaced


Draw Second Floor/ Lower Roof Framing
Draw Third Point Beams In Bay A2-B3
Select Handle On Grid B2-B3
Select Handle On Grid A2-A3
Double Click Right Mouse Key To End Defining Area
Save Linear Elements
Orientation: N-S
Number Of Elements: 2
Draw Surface In Bay A.33.2-B3
Surface: One-Way
Select Handle On Grid Line B2-B3
Double Click Right Mouse Key To End Defining Area
Save Surface Element
Orientation: E-W
Draw Joists In Bay C1-E2
Linear: Narrowly Spaced
Select Handle On Grid C1-C2
Select Handle On Grid E1-E2


Draw Second Floor/ Lower Roof Framing
Draw Joists In Bay C1-E2
Double Click Right Mouse Key To End Defining Area
Save Linear Elements
Orientation: N-S
☒ Spacing: 48"
Draw Surface In Bay C1-E2
Surface: One-Way
Select Handle On Grid C1-C2
Select Handle On Grid E1- E2
Double Click Right Mouse Key To End Defining Area
Save Surface Element
Orientation: E-W
Copy Joists & One-Way Surface To Other Bays
Copy Structure
Select Joists
Select One-Way Surface
Double Click Right Mouse Key To End Selecting Structure
Select Grid Location C1 As The Base Point


Draw Second Floor/ Lower Roof Framing
Copy Joists & One-Way Surface To Other Bays
Paste Structure
Select Grid Locations C2, C3
Double Click Right Mouse Key To End
Draw Trusses
Linear Truss-Custom
Select Grid Locations C2-D2, D2-E2
Double Click Right Mouse Key To End Defining Area
Save Linear Elements
Orientation: E-W
Truss-Custom
Include Opposite Side Of Roof
Depth Of Support: 3'
Scissors Height: 0'
Repeat For Grid Location C3-E3
Draw Columns
Column One Grid Intersection
Select Grid Locations D1, E1, E2, E3, D4, E4


Draw Second Floor/ Lower Roof Framing
Draw Columns
Double Click Right Mouse Key To End Selecting Locations
Save Columns
Orientation: N-S
Height: 14'
All Floors
View Structure
Perspective (3D)
Transparent Object
Show Structure
End


A
B
C
24.0
24.0
1
2
3
4
24.0
24.0
24.0
Upper Roof


A
B
C
D
E
24.0
24.0
18.0
18.0
A.33
8.0
16.0
1
2
3
4
24.0
24.0
24.0
Stairs
Second Floor/Lower Roof



Assign Wall Loads Philosophy





this appproach saves memory

Assign Loads

Start

Use Loads & Design Tool Palette

Assign Live Loads → Select Second Floor/ Lower Roof Horizontal Structural Plane

Use Occupancy (LL)

Highlight: Office 50 psf

Assign Offices 50 psf

	Horizontal	Vertical
Base Point:	24'10"	10"
Point 2:	48'10"	72'10"
Length:	24'0"	72'0"

→ F2 Key For Keyboard Input



Assign Offices 50 psf

	Horizontal	Vertical
Base Point:	10"	48'10"
Point 2:	24'10"	72'10"
Length:	24'0"	24'0"

Highlight: Corridor (main) 100 psf



Assign Corridor (main) 100 psf

	Horizontal	Vertical
Base Point:	8'10"	24'10"
Point 2:	24'10"	48'10"
Length:	16'0"	24'0"

Highlight: Files & Storage 150 psf


Assign Live Loads
Assign Files & Storage 150 psf
Horizontal Vertical
Base Point: 10" 10"
Point 2: 24'10" 24'10"
Length: 24'0" 24'0"
Stop Using Occupancy (LL)
Assign Dead Loads
Assign Floor Loads
Use Floor (DL)
Assign Second Floor Load
Horizontal Vertical
Base Point. 10" 10"
Point 2: 48'10" 24'10"
Length: 48'0" 24'0"
Horizontal Vertical
Base Point: 8'10" 24'10"
Length: 40'0" 24'0"
Assign Second Floor Load
Horizontal Vertical
Base Point: 10" 48'10"
Point 2: 48'10" 72'10"
Length: 48'0" 24'0"
Stop Using Floor (DL)
Assign Roof Loads
Use Roof (DL)
Next Button To View Lower Roof
Assign Lower Roof Load
Horizontal Vertical
Base Point: 48'10" 10"
Point 2: 84'10" 72'10"
Length: 36'0" 72'0"
Stop Using Roof (DL)

Assign Dead Loads

Assign Exterior Wall Loads

Use Wall (DL)

Assign Exterior Wall Load

☒ Assign All Floors

	Horizontal	Vertical
Base Point:	10"	10"
Point 2:	10"	72'10"
Length:	0'0"	72'0"

Next Button To View Exterior Wall



Wall Height

Start: 14'0"
End: 14'0"

Assign Exterior Wall Load

☐ Assign All Floors

	Horizontal	Vertical
Base Point:	10"	10"
Point 2:	48'10"	10"
Length:	48'0"	0'0"



Wall Height

Start: 14'0"
End: 14'0"

Assign Exterior Wall Load

☐ Assign All Floors

	Horizontal	Vertical
Base Point:	48'10"	10"
Point 2:	48'10"	72'10"
Length:	0'0"	72'0"



Wall Height

Start: 14'0"
End: 14'0"

Assign Exterior Wall Load

☐ Assign All Floors

	Horizontal	Vertical
Base Point:	10"	72'10"
Point 2:	48'10"	72'10"
Length:	48'0"	0'0"




Assign Dead Loads
Assign Exterior Wall Loads
Wall Height
Start: 14'0"
End: 14'0"
Assign Parapet Wall Loads
Use Wall (DL)
Assign Parapet Wall Load
Assign All Floors
Horizontal Vertical
Base Point: 48'10" 10"
Point 2: 84'10" 10"
Length: 36'0" 0'0"
Next Button To View Parapet Wall
Wall Height
Start: 4'0"
End: 4'0"
Assign Parapet Wall Load
Assign All Floors
Horizontal Vertical
Base Point: 84'10" 10"
Point 2: 84'10" 72'10"
Length: 0'0" 72'0"
Wall Height
Start: 4'0"
End: 4'0"
Assign Parapet Wall Load
Assign All Floors
Horizontal Vertical
Base Point: 48'10" 72'10"
Point 2: 84'10" 72'10"
Length: 36'0" 0'0"
Wall Height
Start: 4'0"
End: 4'0"
Stop Using Wall (DL)


Assign Dead Loads
Assign Upper Roof Loads
Select Upper Roof Horizontal Structural Plane
Use Roof (DL)
Assign Upper Roof Load
Assign All Floors
Horizontal Vertical
Base Point: 10" 10"
Point 2: 48'10" 72'10"
Length: 48'0" 72'0"
Next Button To View Upper Roof
Stop Using Roof (DL)
Assign Ground Floor Wall Loads
Select Ground Floor Horizontal Structural Plane
Structural Plane Information
Name: Ground Floor
Close Structural Plane Information Dialog Window
Use Wall (DL)
Assign Exterior Wall Load
Assign All Floors
Horizontal Vertical
Base Point: 10" 10"
Point 2: 84'10" 10"
Length: 84'0" 0'0"
Next Button To View Exterior Wall
Wall Height
Start: 14'0"
End: 14'0"


Assign Dead Loads
Assign Ground Floor Wall Loads
Assign Exterior Wall Load
Assign All Floors
Horizontal Vertical
Base Point: 84'10" 10"
Point 2: 84'10" 72'10"
Length: 0'0" 72'0"
Wall Height
Start: 14'0"
End: 14'0"
Assign Exterior Wall Load
Assign All Floors
Horizontal Vertical
Base Point: 10" 72'10"
Point 2: 84'10"
Length: 84'0"
Wall Height
Start: 14'0"
End: 14'0"
Stop Using Wall (DL)
View Loads
Show Loads
None
End


A
B
C
D
E
A.33
24.0
24.0
18.0
18.0
8.0
16.0
1
2
3
4
24.0
24.0
24.0
Office: Offices
(50 psf)
Office: Offices
Office: Corridor (main)
Stairs
(100 psf)
(50 psf)
Office: Files & Storage
(150 psf)
Second Floor/Lower Roof


A
B
C
D
E
A.33
24.0
24.0
18.0
18.0
8.0
16.0
1
2
3
4
24.0
24.0
24.0
Second Floor
(57 psf)
Lower Roof
Second Floor
Exterior Wall
Parapet
(57 psf)
(45 psf)
Second Floor
(57 psf)
Second Floor/Lower Roof



Upper Roof



Ground Floor

Analysis & Design Philosophy

Preliminary Analysis

A. Select:
- * Material
- * Load Combination
  (Live Load Reduction)
- * Element To Analyze



B. Review:
- * Attributes
- * Guidelines

C. Connectivity



D. Self Weight Estimate * Guidelines

E. Analysis
- * Review Loads
- * Connectivity



Pattern Loads



- * Analysis Output
  - I = 1
  - E = 1
  - A = 1000





F. Re-Analysis (with real properties)

Preliminary Design

* Maximum V's, M's, R's, etc. sent to Excel

Spreadsheets



Surface Element Analysis




Preliminary Analysis
Use Preliminary
Analysis
Units: Feet & Pounds
Use Actual Properties
DL=Deck+Self Weight
Decking Analysis
Number Of Spans: 3
Distance From Edge: 12'
Starting Span Number: 1
Include Superimposed Dead Load
Analysis
Analysis File Name: Optional
Yes, The Loads & Connectivity Are Correct
View Shear, Moment & Deflection Diagrams
Excel Data
Execute Excel
End


1.00 Dead (plf)
2.5
1.00 Superimposed Dead (plf)
11.9
1.00 Snow (plf)
25.0
8.0
8.0
8.0
Shear (lb)
126.1
157.6
189.1
-189.1
-157.6
-126.1
Moment (lbft)
201.7
63.0
0.0
0.0
Deflection
39.4
126.1
346.7
346.7
126.1
Total Combined Load

Steel Roof Deck Design



Steel Deck Selection

STEEL ROOF DECK PRELIMINARY SELECTION

Project: Office Building - Scheme A	**Date: Feb 26, 1992**
Location: Radford AAP	**Engr:**

Load and Analysis Data:

Method: Analysis
Member ID:
Connectivity: Beam (Left)
Beam (Right)
Deck Span: 8 ft
Trib Width= 3 in
Depth Limit= 1.5 in. max
Fy= 33.0 ksi
Fb= 20.0 ksi
Fv= 13.2 ksi
E = 29,000 ksi
Live Ld Defl= L/240 =0.53 in
Total Defl= L/180 =0.40 in

Load Combination: D + S

Load Type	Factored Moments (lb-ft) Left	Mid	Right	Fact. Reactions Left(lb)	Right(lb)
Deck	16.0	12.8	16.0	12.0	12.0
Sup Dead	76.2	60.9	76.2	57.1	57.1
Live					
Lmin Roof					
Snow	160.0	128.0	160.0	120.0	120.0
Wind					
Summary	252.2	201.7	252.2	189.1	189.1

Load Combinations for roof:
Load Case #1: D + S
Load Case #2: Deck + Wind
Load Case #3: Deck + Construction 200# Point Load

Est. Deck Wgt = 0.8 psf
Wind Load = -40.0 psf

Deck Configuration:

Deck Type: Roof Deck Cellular: No

Code Load Combinations:

	Case	Load (psf)	Fb Factor	M+ (f-lb)	M- (f-lb)	S+ (in.3)	S- (in.3)	Ix (in.4)
Number of spans = 3	# 1		1.00	201.7	92.2	0.121	0.055	0.0001
	# 2	-39.2	1.33	293.5	-235.8	0.132	-0.106	0.1650
	# 3	0.8	1.33	284.1	-133.1	0.128	-0.060	
Maximums:				293.5	-235.8	0.132	-0.106	0.1650

Steel Roof Deck Selection Table - Spans = 3

Deck Type	Gage	Depth (in)	Sx+ (in.^3)	Sx- (in.^3)	Ix (in.^4)	Dk wgt (psf)	Const Span Limit 1 Span	2+Span
WR 20	20	1.5	0.237	-0.251	0.207	2.2	6'-3"	7'-5"
IR18	18	1.5	0.204	-0.211	0.222	2.8	6'-2"	7'-4"
NR18	18	1.5	0.176	-0.182	0.203	2.9	5'-11"	6'-11"
WR18	18	1.5	0.322	-0.331	0.298	2.9	7'-6"	8'-10"

CASM Preliminary Steel Roof Deck Selection:

Deck Type: WR 20	Span= 8.0 ft	Depth: 1.5 in	Description: 2-1/2"Rib@6"oc
Weight: 2.2 psf	Gage: 20	Ix = 0.207	Construction Load Span Limits:
	Sx+ = 0.237	Sx- = -0.251	1 span: 6'-3" 2+span: 7'-5"

Notes:

1. Steel roof deck properties from representative manufacturer's data.
2. Design calculations from SDI Design Manual for Roof Deck - 1987.

Narrowly Spaced Element Analysis




Preliminary Analysis
Use Preliminary
Analysis
Units: Feet & Pounds
Use Actual Properties
DL=Deck+Self Weight
Connectivity
Left: Hinge
Right: Roller
Self Weight
Estimated Self Weight: 0.0
Analysis
Analysis File Name: Optional
Yes, The Loads & Connectivity Are Correct
View Shear, Moment & Deflection Diagrams
Excel Data
Execute Excel
End


1.00 Dead (plf)
7.2
183.6
1100.8
1.00 Superimposed Dead (plf)
296.0
179.8
179.8
206.3
1.00 Snow (plf)
24.0
4489.1
Shear (lb)
-4816.4
27189.1
Moment (lbft)
0.0
0.0
370.6
370.6
397.1
Deflection
4489.1
4816.4
Total Combined Load

```
*****************************************
* TWO DIMENSIONAL FRAME ANALYSIS PROGRAM *
*****************************************

2-D FRAME ANALYSIS-V 8/77 RUN-Sun Jan 26, 1992  1:10 PM

********************************* I N P U T *********************************

Office Building - Scheme A -- Dead Load

     NUMBER OF ELEMENTS              =   10
     NUMBER OF NODAL POINTS          =   11
     NUMBER OF MATERIALS             =    1
     NUMBER OF ELEMENT TYPES         =    1
     NUMBER OF ELASTIC SUPPORT TYPES =    0
     NUMBER OF FIXED END FORCE TYPES =    1
```

MATERIAL TYPES

UNITS: INCHES, POUNDS

MATERIAL	YOUNG'S MODULUS	POISSON'S RATIO
1	1.0000	0.0000

MEMBER PROPERTIES

UNITS: INCHES

ELEMENT TYPE	AXIAL AREA	SHEAR AREA	MOMENT OF INERTIA
1	1000.0000	0.0000	1.0000

SUMMARY OF IN-SPAN LOADS

POSITIVE IS UPWARD AND COUNTERCLOCKWISE
UNITS: FEET, POUNDS

LOAD SET	LOAD TYPE	SPAN LENGTH	STARTING MAGNITUDE	STARTING POSITION	ENDING MAGNITUDE	ENDING POSITION
1	UNIFORM	2.40	-7.20	0.00		2.40

FIXED END FORCES IN LOCAL COORDINATES

UNITS: FEET, POUNDS

TYPE	AXIAL I	SHEAR I	MOMENT I	AXIAL J	SHEAR J	MOMENT J
1	0.000	8.640	3.456	0.000	8.640	-3.456

JOINT DATA

UNITS: FEET, POUNDS

				BOUNDARY CONDITIONS			
		NODAL COORDINATES		NODAL FORCES AND MOMENTS			ELASTIC
NODE	CODE	X	Y	X	Y	Z	SUPPORT TYPE
1	110	13.00	0.00	0.00	0.00	0.00	0
2	0	15.40	0.00	0.00	0.00	0.00	0
3	0	17.80	0.00	0.00	0.00	0.00	0
4	0	20.20	0.00	0.00	0.00	0.00	0
5	0	22.60	0.00	0.00	0.00	0.00	0
6	0	25.00	0.00	0.00	0.00	0.00	0
7	0	27.40	0.00	0.00	0.00	0.00	0
8	0	29.80	0.00	0.00	0.00	0.00	0
9	0	32.20	0.00	0.00	0.00	0.00	0
10	0	34.60	0.00	0.00	0.00	0.00	0
11	10	37.00	0.00	0.00	0.00	0.00	0

MEMBER DATA

ELE	NODE I	NODE J	MAT TYPE	ELE TYPE	ELE CODE	F.E.F. TYPE	REL KIJ	STIFF KJI	CARRY OVER FACTOR
1	1	2	1	1	0	1	4.00	4.00	0.50
2	2	3	1	1	0	1	4.00	4.00	0.50
3	3	4	1	1	0	1	4.00	4.00	0.50
4	4	5	1	1	0	1	4.00	4.00	0.50
5	5	6	1	1	0	1	4.00	4.00	0.50
6	6	7	1	1	0	1	4.00	4.00	0.50
7	7	8	1	1	0	1	4.00	4.00	0.50
8	8	9	1	1	0	1	4.00	4.00	0.50
9	9	10	1	1	0	1	4.00	4.00	0.50
10	10	11	1	1	0	1	4.00	4.00	0.50

```
******************************** O U T P U T ********************************
```

JOINT DISPLACEMENTS

UNITS: INCHES, RADIANS AFTER DIVISION BY EI

JOINT	X-DISPLACEMENT	Y-DISPLACEMENT	Z-ROTATION
1	0.0000	0.0000	-597196.7842
2	0.0000	-16872481.3041	-563753.7643
3	0.0000	-31921840.2654	-472979.0531
4	0.0000	-43703338.4237	-339207.7734
5	0.0000	-51105019.7359	-170770.2481
6	0.0000	-53747710.5762	-0.0000
7	0.0000	-51105019.7359	170770.2481
8	0.0000	-43703338.4237	339207.7734
9	0.0000	-31921840.2654	472979.0531
10	0.0000	-16872481.3041	563753.7643
11	0.0000	0.0000	597196.7842

MEMBER END FORCES

UNITS: FEET, POUNDS

ELE	AXIAL I	SHEAR I	MOMENT I	AXIAL J	SHEAR J	MOMENT J
1	0.000	86.400	-0.000	0.000	69.120	186.624
2	0.000	69.120	186.624	0.000	51.840	331.776
3	0.000	51.840	-331.776	0.000	34.560	435.456
4	0.000	34.560	-435.456	0.000	17.280	497.664
5	0.000	[illegible]	[illegible]	0.000	-0.000	518.400
6	0.000	0.000	-518.400	0.000	17.280	497.664
7	0.000	-17.280	-497.664	0.000	34.560	435.456
8	0.000	-34.560	-435.456	0.000	51.840	331.776
9	0.000	-51.840	-331.776	0.000	69.120	186.624
10	0.000	-69.120	-186.624	0.000	86.400	0.000

APPLIED JOINT LOADS AND SUPPORT REACTIONS

UNITS: FEET, POUNDS

NODE	FORCE X	FORCE Y	MOMENT Z
1	0.000	86.400	-0.000
2	0.000	0.000	0.000
3	0.000	-0.000	0.000
4	0.000	0.000	0.000
5	0.000	-0.000	-0.000
6	0.000	0.000	0.000
7	0.000	-0.000	0.000
8	0.000	-0.000	0.000
9	0.000	0.000	0.000
10	0.000	-0.000	0.000
11	0.000	86.400	0.000

```
**PROBLEM COMPLETED**

*****************************************
* TWO DIMENSIONAL FRAME ANALYSIS PROGRAM *
*****************************************

2-D FRAME ANALYSIS-V 8/77 RUN-Sun Jan 26, 1992  1:10 PM

********************************* I N P U T *********************************

Office Building - Scheme A -- Superimposed Dead Load
```

NUMBER OF ELEMENTS = 10
NUMBER OF NODAL POINTS = 11
NUMBER OF MATERIALS = 1
NUMBER OF ELEMENT TYPES = 1
NUMBER OF ELASTIC SUPPORT TYPES = 0
NUMBER OF FIXED END FORCE TYPES = 1

MATERIAL TYPES

UNITS: INCHES, POUNDS

MATERIAL	YOUNG'S MODULUS	POISSON'S RATIO
1	1.0000	0.0000

MEMBER PROPERTIES

UNITS: INCHES

ELEMENT TYPE	AXIAL AREA	SHEAR AREA	MOMENT OF INERTIA
1	1000.0000	0.0000	1.0000

SUMMARY OF IN-SPAN LOADS

POSITIVE IS UPWARD AND COUNTERCLOCKWISE
UNITS: FEET, POUNDS

LOAD SET	LOAD TYPE	SPAN LENGTH	STARTING MAGNITUDE	STARTING POSITION	ENDING MAGNITUDE	ENDING POSITION
1	UNIFRM	2.40	-183.60	0.00		2.40

FIXED END FORCES IN LOCAL COORDINATES

UNITS: FEET, POUNDS

TYPE	AXIAL I	SHEAR I	MOMENT I	AXIAL J	SHEAR J	MOMENT J
1	0.000	440.640	88.128	0.000	220.320	-88.128

JOINT DATA

UNITS: FEET, POUNDS

NODE	CODE	NODAL COORDINATES X	NODAL COORDINATES Y	BOUNDARY CONDITIONS NODAL FORCES AND MOMENT X	BOUNDARY CONDITIONS Y	BOUNDARY CONDITIONS Z	ELASTIC SUPPORT TYPE
1	110	13.00	0.00	0.00	0.00	0.00	0
2	0	15.60	0.00	0.00	0.00	0.00	0
3	0	17.00	0.00	0.00	0.00	0.00	0
4	0	20.20	0.00	0.00	0.00	0.00	0
5	0	22.60	0.00	0.00	0.00	0.00	0
6	0	25.00	0.00	0.00	0.00	0.00	0
7	0	27.40	0.00	0.00	0.00	0.00	0
8	0	29.80	0.00	0.00	0.00	0.00	0
9	0	32.20	0.00	0.00	0.00	0.00	0
10	0	34.60	0.00	0.00	0.00	0.00	0
11	10	37.00	0.00	0.00	0.00	0.00	0

MEMBER DATA

ELE	NODE I	NODE J	MAT TYPE	ELE TYPE	ELE CODE	F.E.F. TYPE	REL. K/J	STIFF K/I	CARRY OVER FACTOR
1	1	2	1	1	0	1	4.00	4.00	0.50
2	2	3	1	1	0	1	4.00	4.00	0.50
3	3	4	1	1	0	1	4.00	4.00	0.50
4	4	5	1	1	0	1	4.00	4.00	0.50
5	5	6	1	1	0	1	4.00	4.00	0.50
6	6	7	1	1	0	1	4.00	4.00	0.50
7	7	8	1	1	0	1	4.00	4.00	0.50
8	8	9	1	1	0	1	4.00	4.00	0.50
9	9	10	1	1	0	1	4.00	4.00	0.50
10	10	11	1	1	0	1	4.00	4.00	0.50

********** O U T P U T **********

JOINT DISPLACEMENTS

UNITS: INCHES, RADIANS AFTER DIVISION BY EI

JOINT	X-DISPLACEMENT	Y-DISPLACEMENT	Z-ROTATION
1	0.0000	0.0000	-15236816.6680
2	0.0000	-430246292.2560	-14378721.6235
3	0.0000	-614064962.7674	-12960966.7856
4	0.0000	-1116435179.0064	-6640790.6640
5	0.0000	-1306210660.0829	-4597661.5260
6	0.0000	-1376560680.2861	-0.0000
7	0.0000	-1306210660.0829	4597661.5260
8	0.0000	-1116435179.0064	6640790.6640
9	0.0000	-614064962.7674	12960966.7856
10	0.0000	-430246292.2560	14378721.6235
11	0.0000	0.0000	15236816.6680

MEMBER END FORCES

UNITS: FEET, POUNDS

ELE	AXIAL I	SHEAR I	MOMENT I	AXIAL J	SHEAR J	MOMENT J
1	0.000	2263.200	0.000	0.000	-1762.560	4750.912
2	0.000	1762.560	-4750.912	0.000	-1321.920	8460.288
3	0.000	1321.920	-8460.288	0.000	-881.280	11186.126
4	0.000	881.280	-11186.126	0.000	-440.640	12890.433
5	0.000	440.640	-12890.433	0.000	0.000	13219.201
6	0.000	-0.000	-13219.201	0.000	440.640	12890.433
7	0.000	-440.640	-12890.433	0.000	881.280	11186.126
8	0.000	-881.280	-11186.126	0.000	1321.920	8460.288
9	0.000	-1321.920	-8460.288	0.000	1762.560	4750.912
10	0.000	-1762.560	-4750.912	0.000	2263.200	-0.000

APPLIED JOINT LOADS AND SUPPORT REACTIONS

UNITS: FEET, POUNDS

NODE	FORCE X	FORCE Y	MOMENT Z
1	0.000	2263.200	0.000
2	0.000	-0.000	0.000
3	0.000	0.000	-0.000
4	0.000	0.000	-0.000
5	0.000	-0.000	-0.000
6	0.000	0.000	-0.000
7	0.000	0.000	-0.000
8	0.000	0.000	0.000
9	0.000	0.000	0.000
10	0.000	-0.000	0.000
11	0.000	2263.200	-0.000

PROBLEMS COMPLETED

****
* THE 2-DIMENSIONAL FRAME ANALYSIS PROGRAM *
****

2-D FRAME ANALYSIS-V 6/77 EMU-Sun Jan 26, 1992 1:10 PM

********** I N P U T **********

Office Building - Column A — Snow Load

NUMBER OF ELEMENTS = 10
NUMBER OF NODAL POINTS = 11
NUMBER OF MATERIALS = 1
NUMBER OF ELEMENT TYPES = 1
NUMBER OF ELASTIC SUPPORT TYPES = 0
NUMBER OF FIXED END FORCE TYPES = 1

MATERIAL TYPES

UNITS: INCHES, POUNDS

MATERIAL	YOUNG'S MODULUS	POISSON'S RATIO
1	1.0000	0.0000

MEMBER PROPERTIES

UNITS: INCHES

ELEMENT TYPE	AXIAL AREA	SHEAR AREA	MOMENT OF INERTIA
1	1000.0000	0.0000	1.0000

SUMMARY OF IN-SPAN LOADS

POSITIVE IS UPWARD AND COUNTERCLOCKWISE
UNITS: FEET, POUNDS

LOAD SET	LOAD TYPE	SPAN LENGTH	STARTING MAGNITUDE	STARTING POSITION	ENDING MAGNITUDE	ENDING POSITION
1	UNIFRM	2.40	-179.76	0.00		2.40
2	UNIFRM	2.40	-179.76	0.00		1.32
2	RAMP	2.40	-179.76	1.32	-189.06	2.40
3	RAMP	2.40	-189.06	0.00	-206.35	2.00
3	RAMP	2.40	-206.35	2.00	-213.18	2.40
4	RAMP	2.40	-213.18	0.00	-256.59	2.40
5	RAMP	2.40	-256.59	0.00	-296.00	2.40

FIXED END FORCES IN LOCAL COORDINATES

UNITS: FEET, POUNDS

TYPE	AXIAL I	SHEAR I	MOMENT I	AXIAL J	SHEAR J	MOMENT J
1	0.000	215.713	86.285	0.000	215.713	-86.285
2	0.000	216.128	86.581	0.000	220.311	-87.387
3	0.000	234.236	94.731	0.000	244.033	-96.788
4	0.000	270.727	110.276	0.000	290.683	-114.256
5	0.000	320.617	130.154	0.000	340.253	-134.138

JOINT DATA

UNITS: FEET, POUNDS

NODE	CODE	NODAL COORDINATES X	NODAL COORDINATES Y	BOUNDARY CONDITIONS NODAL FORCES AND MOMENTS X	Y	Z	ELASTIC SUPPORT TYPE
1	110	13.00	0.00	0.00	0.00	0.00	0
2	0	15.40	0.00	0.00	0.00	0.00	0
3	0	17.80	0.00	0.00	0.00	0.00	0
4	0	20.20	0.00	0.00	0.00	0.00	0
5	0	22.60	0.00	0.00	0.00	0.00	0
6	0	25.00	0.00	0.00	0.00	0.00	0
7	0	27.40	0.00	0.00	0.00	0.00	0
8	0	29.80	0.00	0.00	0.00	0.00	0
9	0	32.20	0.00	0.00	0.00	0.00	0
10	0	34.60	0.00	0.00	0.00	0.00	0
11	10	37.00	0.00	0.00	0.00	0.00	0

MEMBER DATA

ELE	NODE I	NODE J	MAT TYPE	ELE TYPE	ELE CODE	F.E.F. TYPE	REL RIJ	STIFF RJI	CARRY OVER FACTOR
1	1	2	1	1	0	1	4.00	4.00	0.50
2	2	3	1	1	0	1	4.00	4.00	0.50
3	3	4	1	1	0	1	4.00	4.00	0.50
4	4	5	1	1	0	1	4.00	4.00	0.50
5	5	6	1	1	0	1	4.00	4.00	0.50
6	6	7	1	1	0	1	4.00	4.00	0.50
7	7	8	1	1	0	2	4.00	4.00	0.50
8	8	9	1	1	0	3	4.00	4.00	0.50
9	9	10	1	1	0	4	4.00	4.00	0.50
10	10	11	1	1	0	5	4.00	4.00	0.50

********** O U T P U T **********

JOINT DISPLACEMENTS

UNITS: INCHES, RADIANS AFTER DIVISION BY EI

JOINT	X-DISPLACEMENT	Y-DISPLACEMENT	Z-ROTATION
1	0.0000	0.0000	-15477674.9666
2	0.0000	-437429479.1567	-14625130.2757
3	0.0000	-829238839.9028	-13306057.6766
4	0.0000	-1135615612.7337	-8878299.3904
5	0.0000	-1332510743.5772	-4699697.0362
6	0.0000	-1402544784.3923	-1280964.6233
7	0.0000	-1339551587.7742	4478667.3991
8	0.0000	-1147671481.9354	8702676.2217
9	0.0000	-841613597.1693	12358723.8440
10	0.0000	-446232743.7972	14868920.1648
11	0.0000	0.0000	15819665.5336

MEMBER END FORCES

UNITS: FEET, POUNDS

ELE	AXIAL I	SHEAR I	MOMENT I	AXIAL J	SHEAR J	MOMENT J
1	0.000	2199.520	0.000	0.000	-1760.896	4761.137
2	0.000	1768.896	-4761.137	0.000	-1336.668	8486.882
3	0.000	1336.668	-8486.882	0.000	-908.241	11177.143
4	0.000	905.241	-11177.143	0.000	-473.815	12832.811
5	0.000	473.815	-12832.811	0.000	-42.389	13451.456
6	0.000	42.389	-13451.456	0.000	389.037	13033.677
7	0.000	-389.037	-13035.677	0.000	825.477	11582.273
8	0.000	-825.477	-11582.273	0.000	1304.746	9036.668
9	0.000	-1304.746	-9036.668	0.000	1866.076	5251.556
10	0.000	-1866.076	-5251.556	0.000	2526.785	-0.000

APPLIED JOINT LOADS AND SUPPORT REACTIONS

UNITS: FEET, POUNDS

NODE	FORCE X	FORCE Y	MOMENT Z
1	0.000	2199.520	0.000
2	0.000	-0.000	0.000
3	0.000	-0.000	0.000
4	0.000	0.000	-0.000
5	0.000	0.000	-0.000
6	0.000	0.000	0.000
7	0.000	0.000	0.000
8	0.000	-0.000	-0.000
9	0.000	0.000	0.000
10	0.000	-0.000	0.000
11	0.000	2526.785	-0.000

PROBLEM CONCLUDED

****
* TWO DIMENSIONAL FRAME ANALYSIS PROGRAM *
****

2-D FRAME ANALYSIS-V 6/77 NIH-Dec Jan 26 1982 1:10 PM

********** I N P U T **********

Office Building - Scheme A -- Total Combined Load

NUMBER OF ELEMENTS = 10
NUMBER OF NODAL POINTS = 11
NUMBER OF MATERIALS = 1
NUMBER OF ELEMENT TYPES = 1
NUMBER OF ELASTIC SUPPORT TYPES = 0
NUMBER OF FIXED END FORCE TYPES = 5

MATERIAL TYPES

UNITS: INCHES, POUNDS

MATERIAL	YOUNG'S MODULUS	POISSON'S RATIO
1	1.0000	0.0000

MEMBER PROPERTIES

UNITS: INCHES

ELEMENT TYPE	AXIAL AREA	SHEAR AREA	MOMENT OF INERTIA
1	1000.0000	0.0000	1.0000

SUMMARY OF IN-SPAN LOADS

POSITIVE IS UPWARD AND COUNTERCLOCKWISE
UNITS: FEET, POUNDS

LOAD SET	LOAD TYPE	SPAN LENGTH	STARTING MAGNITUDE	STARTING POSITION	ENDING MAGNITUDE	ENDING POSITION
1	UNIFRM	2.40	-370.56	0.00		2.40
2	UNIFRM	2.40	-190.80	0.00		2.40
2	UNIFRM	2.40	-179.76	0.30		1.32
2	RAMP	2.40	-179.76	1.32	-189.06	2.40
3	UNIFRM	2.40	-190.80	0.00		2.40
3	RAMP	2.40	-189.06	0.30	-206.35	2.30
3	RAMP	2.40	-206.35	2.30	-213.18	2.40
4	UNIFRM	2.40	-190.80	0.00		2.40
4	RAMP	2.40	-213.18	0.70	-256.59	2.40
5	UNIFRM	2.40	-190.80	0.00		2.40
5	RAMP	2.40	-256.59	0.00	-296.00	2.40

FIXED END FORCES IN LOCAL COORDINATES

UNITS: FEET, POUNDS

TYPE	AXIAL I	SHEAR I	MOMENT I	AXIAL J	SHEAR J	MOMENT J
1	0.000	444.673	177.869	0.000	444.673	-177.869
2	0.000	445.888	178.165	0.000	449.271	-178.971
3	0.000	463.296	184.315	0.000	473.893	-188.372
4	0.000	499.887	201.862	0.000	519.583	-205.838
5	0.000	549.377	221.730	0.000	569.283	-225.714

JOINT DATA

UNITS: FEET, POUNDS

		NODAL COORDINATES		BOUNDARY CONDITIONS: NODAL FORCES AND MOMENTS			ELASTIC
NODE	CODE	X	Y	X	Y	Z	SUPPORT TYPE
1	110	13.00	0.00	0.00	0.00	0.00	0
2	0	15.40	0.00	0.00	0.00	0.00	0
3	0	17.80	0.00	0.00	0.00	0.00	0
4	0	20.20	0.00	0.00	0.00	0.00	0
5	0	22.60	0.00	0.00	0.00	0.00	0
6	0	25.00	0.00	0.00	0.00	0.00	0
7	0	27.40	0.00	0.00	0.00	0.00	0
8	0	29.80	0.00	0.00	0.00	0.00	0
9	0	32.20	0.00	0.00	0.00	0.00	0
10	0	34.60	0.00	0.00	0.00	0.00	0
11	10	37.00	0.00	0.00	0.00	0.00	0

MEMBER DATA

ELE	NODE I	NODE J	MAT TYPE	ELE TYPE	ELE CODE	F.E.F. TYPE	REL KIJ	STIFF KJI	CARRY OVER FACTOR
1	1	2	1	1	0	1	4.00	4.00	0.50
2	2	3	1	1	0	1	4.00	4.00	0.50
3	3	4	1	1	0	1	4.00	4.00	0.50
4	4	5	1	1	0	1	4.00	4.00	0.50
5	5	6	1	1	0	1	4.00	4.00	0.50
6	6	7	1	1	0	1	4.00	4.00	0.50
7	7	8	1	1	0	2	4.00	4.00	0.50
8	8	9	1	1	0	3	[illegible]	[illegible]	0.50
9	9	10	1	1	0	4	4.00	4.00	0.50
10	10	11	1	1	0	5	4.00	4.00	0.50

******************************** O U T P U T ********************************

JOINT DISPLACEMENTS

UNITS: INCHES, RADIANS AFTER DIVISION BY EI

JOINT	X-DISPLACEMENT	Y-DISPLACEMENT	Z-ROTATION
1	0.0000	0.0000	-31383390.4217
2	0.0000	-444080240.7108	-29664008.0636
3	0.0000	-1474257630.0586	-24840024.3158
4	0.0000	-2232782530.1680	-17067308.7676
5	0.0000	-2680913004.2081	-9384109.4106
6	0.0000	-2826850173.3740	-120094.4333
7	0.0000	-2680984880.4031	9163079.1732
8	0.0000	-2308080090.3679	17731608.6991
9	0.0000	-1687342400.1422	24692600.4029
10	0.0000	-893384817.3313	29006003.3823
11	0.0000	0.0000	31848300.9090

MEMBER END FORCES

UNITS: FEET, POUNDS

ELE	AXIAL I	SHEAR I	MOMENT I	AXIAL J	SHEAR J	MOMENT J
1	0.000	4409.120	0.000	0.000	-3599.774	9700.674
2	0.000	3599.774	-9700.674	0.000	-2710.420	17270.910
3	0.000	2710.420	-17270.910	0.000	-1821.081	22716.727
4	0.000	1821.081	-22716.727	0.000	-931.735	26020.107
5	0.000	931.735	-26020.107	0.000	-42.389	27109.055
6	0.000	42.389	-27109.055	0.000	840.987	26223.574
7	0.000	-840.987	-26223.574	0.000	1741.317	23121.839
8	0.000	-1741.317	-23121.839	0.000	2678.806	17828.732
9	0.000	-2678.806	-17828.732	0.000	3697.756	10197.894
10	0.000	-3697.756	-10197.894	0.000	4816.386	0.000

APPLIED JOINT LOADS AND SUPPORT REACTIONS

UNITS: FEET, POUNDS

NODE	FORCE X	FORCE Y	MOMENT Z
1	0.000	4409.120	0.000
2	0.000	-0.000	0.000
3	0.000	0.000	0.000
4	0.000	0.000	-0.000
5	0.000	0.000	-0.000
6	0.000	-0.000	-0.000
7	0.000	0.000	-0.000
8	0.000	0.000	0.000
9	0.000	-0.000	0.000
10	0.000	-0.000	0.000
11	0.000	4816.386	0.000

PROBLEM COMPLETED

Steel Open-Web Joist Design



Barjoist Selection

STEEL BAR JOIST PRELIMINARY SELECTION

Project: Office Building - Scheme A	Date: Feb 26, 1992
Location: Radford AAP	Engr:

CASM Load & Analysis Data:

Method: Analysis
Member ID:
Connection: Hinge (Left)
Roller (Right)
Span: 24.0 ft
Spacing: 48.0 in
Depth Limit= 24.0 in. max
Fy= 36.0 ksi
Fb= 24.0 ksi
E = 29,000 ksi
Live Defl= L/360= 0.80 in
Total Defl= L/240= 1.20 in

Load Combination: D + S

LoadType	Factored Moment (ft-lb) Left	Mid	Right	Factored Reaction Left(lb)	Right(lb)
Dead		518		86	86
Sup Dead		13,219		2,203	2,203
Live					
Lmin Roof					
Snow		13,451		2,200	2,527
Wind					
Summary		27,188		4,489	4,816

Moment: (EUL)		Reaction: (EUL)	
Total Ld=	378 plf	Total Ld=	401 plf
Live Ld=	187 plf	Live Ld=	211 plf

CASM Joist Selection Table: (joist capacities)

Joist Size	Spacing (in)	Total Ld(plf)	Live Ld(plf)	Mmax (ftlb)	Rmax (lb)	Live Ld Defl(in)	Total Ld Defl(in)	Joist Weight (psf)	(plf)
20K4	48.0	430	353	30,960	5,160	0.48	0.92	1.9	7.6
18K5	48.0	434	318	31,248	5,208	0.54	1.03	1.9	7.7
22K4	48.0	475	431	34,200	5,700	0.40	0.76	2.0	8.0
16K6	48.0	418	269	30,096	5,016	0.63	1.21	2.0	8.1

CASM Bar Joist Selection:

Joist Size:	20K4	Span:	24.0 ft	Spacing:	48 in	Total Ld:	430 plf	Live Ld:	353 plf
Wgt(tons):	0.09	Mmax:	30,960	Rmax:	5,160	TL defl:	0.92 in	LL defl:	0.48 in

NOTES:

1. Bar joist selections based on 1988 SJI Load Tables.
   Edit spreadsheet stajstk.xls to revise selection table.
2. Approximate moment of inertia of the joist in inches^4 is:
   Ij = 26.767 (WLL) (L^3) (10^-6), where WLL = Live Load value in table;
   where L = Span - 0.33 in feet

Widely Spaced Element Analysis: Beam






Preliminary Analysis
Use Preliminary
Analysis
Units: Feet & Kips
Use Actual Properties
DL=Deck+Self Weight
Connectivity
Left: Hinge
Right: Roller
Self Weight
Guidelines
Find Estimate For 24' Span & 1.65 kJ
Close Self Weight Guidelines Dialog Window
Self Weight
Estimated Self Weight: 50 plf
Update Area Structure Loads
Add Self Weight
Analysis
Analysis File Name: Optional
Yes, The Loads & Connectivity Are Correct
View Shear, Moment & Deflection Diagrams
Excel Data
Execute Excel
End


1.00 Dead (klf)
0.05
8.20
0.46
1.00 Superimposed Dead (klf)
1.20
.00 Live (klf)
24.0


20.5
Shear (k)
-20.5
122.8
Moment (kft)
0.0
0.0


.71
8.20
Deflection
20.47
20.47
otal Combined Load

Steel Beam Design



Steel Beam Selection

STEEL BEAM PRELIMINARY SELECTION

Project: Office Building - Scheme A	Date: Feb 26, 1992
Location: Radford AAP	Engr:

CASM Load & Analysis Data:

Method: Analysis
Member ID:
Connectivity: Hinge (Left)
Roller (Right)
Beam Span: 24.0 ft
Trib Width= 8.0 ft
Depth Limit= 36.0 in. max
Fy= 36.0 ksi
Fb=.66*Fy= 24.0 ksi
Fv= 14.4 ksi
E = 29,000 ksi
Live Ld Defl= L/360 =0.80 in
Total Defl= L/240 =1.20 in

Load Combination: D + L

Load Type	Factored Moments (k-ft) Left	Mid	Right	Fact. Reactions Left(k)	Right(k)
Dead		3.6		0.6	0.6
Sup Dead		32.8		5.5	5.5
Live		86.4		14.4	14.4
Lmin Roof					
Snow					
Wind					
Summary		122.8		20.5	20.5

Max: M=	122.8 k-ft	R=	20.5 kips
Sx(req)=	61.4 in^3	Ix(req)=	386.1 in^4

CASM Beam Selection Table:

Beam	Depth d (in)	Width bf (in)	Ix (in^4)	Sx (in^3)	Live Ld Defl (in)	Total Ld Defl (in)	Shear fv (ksi)	Bending fb (ksi)	Beam Wt (lb)
W 14 x 43	13.7	8.00	428	63	-0.72	-1.03	4.9	23.5	1,032
W 12 x 50	12.2	8.08	394	65	-0.78	-1.11	4.5	22.8	1,200
W 16 x 40	16.0	7.00	518	65	-0.60	-0.85	4.2	22.8	960
W 18 x 40	17.9	6.02	612	68	-0.50	-0.72	3.6	21.5	960
W 14 x 48	13.8	8.03	485	70	-0.64	-0.91	4.4	21.0	1,152

CASM Steel Beam Selection:

						Live / Total	
W 16 x 40	Span= 24.0 ft	Ix=	518	Sx=	65	Defl(in):	-0.60 -0.85
		fv=	4.2	fb=	3.8	Beam Wt(tons)=	0.48

Notes:

1. Steel beam properties from ASD - AISC Steel Construction Manual, 9th edition

Widely Spaced Element Analysis: Girder






Preliminary Analysis
Use Preliminary
Analysis
Units: Feet & Kips
Use Actual Properties
DL=Deck+Self Weight
Connectivity
Left: Hinge
Right: Roller
Self Weight
Estimated Self Weight: 73 plf
Update Area Structure Loads
Add Self Weight
Analysis
Analysis File Name: Optional
Yes, The Loads & Connectivity Are Correct
View Shear, Moment & Deflection Diagrams
Excel Data
Execute Excel
End













Total Combined Load

Steel Beam Design



Steel Beam Selection

STEEL BEAM PRELIMINARY SELECTION

Project: Office Building - Scheme A	Date: Feb 26, 1992
Location: Radford AAP	Engr:

CASM Load & Analysis Data:

Method: Analysis

Member ID:

Connectivity: Hinge (Left)
Roller (Right)

Beam Span: 24.0 ft

Trib Width= 24.0 ft

Depth Limit= 36.0 in. max

Fy= 36.0 ksi

Fb=.66*Fy= 24.0 ksi

Fv= 14.4 ksi

E = 29,000 ksi

Live Ld Defl= L/360 =0.80 in

Total Defl= L/240 =1.20 in

Load Combination: D + L

Load Type	Factored Moments (k-ft) Left	Mid	Right	Fact. Reactions Left(k)	Right(k)
Dead		13.7		1.9	2.0
Sup Dead		80.3		9.1	10.0
Live		179.2		20.8	22.4
Lmin Roof					
Snow					
Wind					
Summary		272.9		31.8	34.4

Max:	M= 272.9 k-ft	R=	34.4 kips
	Sx(req)= 136.5 in^3	Ix(req)=	769.4 in^4

CASM Beam Selection Table:

Beam	Depth d (in)	Width bf (in)	Ix (in^4)	Sx (in^3)	Live Ld Defl (in)	Total Ld Defl (in)	Shear fv (ksi)	Bending fb (ksi)	Beam Wt (lb)
W 21 x 68	21.1	8.27	1,480	140	-0.43	-0.65	3.8	23.4	1,632
W 14 x 90	14.0	14.52	999	143	-0.63	-0.96	5.6	22.9	2,160
W 12 x 106	12.9	12.22	933	145	-0.68	-1.03	4.4	22.6	2,544
W 18 x 76	18.2	11.04	1,330	146	-0.47	-0.72	4.4	22.4	1,824
W 21 x 73	21.2	8.30	1,600	151	-0.39	-0.60	3.6	21.7	1,752

CASM Steel Beam Selection:

						Live / Total	
W 21 x 68	Span= 24.0 ft	Ix=	1,480	Sx=	140	Defl(in):	-0.43 -0.65
		fv=	3.8	fb=	2.7	Beam Wt(tons)=	0.82

Notes:

1. Steel beam properties from ASD - AISC Steel Construction Manual, 9th edition

Truss Element Analysis




Preliminary Analysis
Analysis
Units: Feet & Kips
Use Actual Properties
DL=Deck+Self Weight
Connectivity
Left: Hinge
Right: Roller
Truss - Custom
Pratt
Top Chord Panels: 9
Depth At Supports: 3'
Scissors Height: 0'
Verticals
Start At Bottom
Left Support At Top
Right Support At Top
Try Other Configurations
Self Weight
Guidelines
Find Estimate For 36' Span & Flat Pitch
Close Self Weight Guidlines Dialog Window
Self Weight
Estimated Self Weight: 96 plf
Update Area Structure Loads
Add Self Weight
4 plf x 24' o.c.
Analysis
Analysis File Name: Optional
Yes, The Loads & Connectivity Are Correct
View Axial, Reactions & Deflection Diagrams
Cancel Linear Element
End



1.00 Dead (klf)



1.00 Superimposed Dead (klf)



1.00 Snow (klf)







Total Combined Load -- Axial (k)



Total Combined Load -- Deflection



Total Combined Load -- Reactions (k)

Column Load Run Down






Preliminary Analysis
Use Preliminary
Analysis
Units: Feet & Kips
Use Actual Properties
DL=Deck+Self Weight
Live Load Reduction
Occupancy Is Public Assembly Or Garage
File Name: Llrout.txt
Self Weight
Estimated Self Weight: 36 plf
View Column Load Run Down
Excel Data
Execute Excel
View Calculations After Design
Print Data
Live Load Reduction
All Other
Print To File
Execute Notepad
Scroll Output
Page Setup
Left Margin: 0.5 in
Right Margin: 0.0 in
Print File
Exit Notepad


Live Load Reduction
Occupancy (LL)
Apply Live Load Reduction
End



	Tributary Area	Self Weight	DL	LLR	LLR	S	TL	Sum DL	Sum LLR	Sum S	Sum TL
Upper Roof	576.0		8.3	0.0	0.0	14.4	22.7				
		0.5						8.8	0.0	14.4	23.2
Second Floor/Lower Roof	576.0		36.4		37.8	0.0	74.2				
		0.5						45.7	37.8	14.4	97.9

Column B-3 Load Run Down (k)

```
Project     : Office Building - Scheme A
Location    : Radford AAP
Design Load : TM 5-809-1 1991
Time        : Sun Jan 26, 1992  1:13 PM

************************** Live Load Reduction **************************

Second Floor/Lower Roof
Office: Offices                (Lo) :   50.0 psf
Tributary area                 (TA) :  576.0 sf
Area of influence (Ai) = 4*TA for columns.
Ai = 2304.0 sf
Ai >= 400.0 sf
Lo <= 100.0 psf
L = Lo*[0.25+15/sqrt(Ai)]
L = 28.1 psf
Member supports only one floor.
L >= 0.5*Lo
0.5*Lo = 25.0 psf
+------------------------+
|     L = 28.13 psf      |
+------------------------+

************************** Live Load Reduction **************************

Second Floor/Lower Roof
Office: Corridor (main)        (Lo) :  100.0 psf
Tributary area                 (TA) :  576.0 sf
Area of influence (Ai) = 4*TA for columns.
Ai = 2304.0 sf
Ai >= 400.0 sf
Lo <= 100.0 psf
L = Lo*[0.25+15/sqrt(Ai)]
L = 56.3 psf
Member supports only one floor.
L >= 0.5*Lo
0.5*Lo = 50.0 psf
+------------------------+
|     L = 56.25 psf      |
+------------------------+

************************** Live Load Reduction **************************

Second Floor/Lower Roof
Office: Files & Storage        (Lo) :  150.0 psf
Tributary area                 (TA) :  576.0 sf
Area of influence (Ai) = 4*TA for columns.
Ai = 2304.0 sf
Ai >= 400.0 sf
Lo > 100.0 psf
Member supports only one floor.
No live load reduction taken.
L = Lo
+------------------------+
|     L = 150.00 psf     |
+------------------------+
```

Steel Column Design



Steel Column Preliminary Selection

STEEL COLUMN PRELIMINARY SELECTION

Project: Office Building - Scheme A	Date: Feb 26, 1992
Location: Radford AAP	Engr:

CASM Load & Analysis Data:

Method: Analysis Load Combination: D + L + S Steel Fy= 36.0 ksi
Member ID: B-3 Size Limit= 16.0 in. max E= 29000 ksi

Name	Level	Flr to Flr Ht	Trib Area	Floor Level Load Totals (kips)					Load Totals
				Dead	Live	Lmin	Snow	Wind	
	6								
	5								
	4								
	3								
Upper Roof	2	14.0	576	8.8			14.4		23.2
Second Floor/L	1	14.0	576	45.7	37.8		14.4		97.9

CASM Column Selection Table

Level: 2 Preq: 23.2 kips K-value: 1.0 Cc= 126.1
Col Shape: W Length: 14.0 ft kl: 14.0

Column Size	Depth d(in)	Width bf(in)	Area (sq in)	ry (in)	kl/r	Fa (ksi)	fa (ksi)	Pallow (kip)	Weight (ton)
W 6 x 15	5.99	5.99	4.43	1.46	115.07	10.98	5.24	48.6	0.11
W 5 x 16	5.01	5.00	4.68	1.27	132.28	8.45	4.96	39.6	0.11
W 8 x 18	8.14	5.25	5.26	1.23	136.59	7.78	4.41	40.9	0.13
W 5 x 19	5.15	5.03	5.54	1.28	131.25	8.61	4.19	47.7	0.13
W 8 x 28	8.06	6.54	8.25	1.62	103.70	12.50	2.81	103.2	0.20

CASM Steel Column Selection

Column Size	Level	Depth d(in)	Width bf(in)	Area (sq in)	ry (in)	kl/r	Fa (ksi)	Pallow (kip)	Weight (ton)
W 8 x 28	2	8.06	6.54	8.25	1.62	103.70	12.50	103.2	0.20
W 8 x 28	1	8.06	6.54	8.25	1.62	103.70	12.50	103.2	0.20

Total Column Weight: 0.20

Notes:

1. Steel column properties from ASD - AISC Steel Construction Manual, 9th edition

Lateral Resistance Philosophy

Steps Required

1. Create building volume

2. Define a structural grid

3. Layout structural framing on ALL levels

4. Assign gravity load on ALL levels
   Calculate wind and/or seismic loads

5. Select a load combination including wind or seismic loads

6. Define N-S & E-W vertical resistance system

   Options:

   1. Unbraced Frames



   2. Braced Frames

      A. Trussing



      B. Shear Walls



7. Define horizontal diaphragm systems

   All flexible
   All rigid
   Floors rigid & roof flexible

Flexible Diaphragms

Simple Beam Model
(tributary area)



* No Torsion

Continuous Beam Model



Rigid Diaphragms

Symmetrical



Torsion
(even accidental minimum required)

Non-Symmetrical



Monolithic Perpendicular Shear Walls



For N-S



For E-W



Define Lateral Resistance




Define E-W Lateral Resistance
Define Location
Vertical Define Location
Select Beam On Grid Line 1
Define Bracing & Connectivity
Vertical Define Elements
Select EW-1
Define All Rigid Frame Connections
Close Lateral Resistance Dialog
Repeat For Grid Line 4
Define Upper Roof Diaphragm Type
Select Upper Roof Horizontal Structural Plane
Lateral Horizontal Flexible Diaphragm
Display Lateral Resistance Locations
Show Structure
NS Lateral Resistance
EW Lateral Resistance
End


A
B
C
D
E
A.33
24.0
24.0
18.0
18.0
8.0
16.0
1
2
3
4
24.0
24.0
24.0
NS-Stairs
NS-2
NS-3
Rigid Diaphragm
Second Floor/Lower Roof


1
2
3
4
24.0
24.0
24.0
28.0
14.0
14.0
14.0
0.0

NS-1 & NS-2


1
2
3
4
24.0
24.0
24.0
Rigid
14.0
14.0
0.0

NS-3


A
E
C
D
E
24.0
24.0
18.0
18.0
Rigid
28.0
14.0
Rigid
14.0
14.0
0.0

EW-1 & EW-2

Wind Lateral Analysis




Define Properties
Beam Properties
Use Copy Design
Select Beam With Properties
Select All Other Beams Used For NS-1, NS-2, NS-3, EW-1, EW-2
Double Click Right Mouse Key To End Copying Designs
Column Properties
Use Modify Design
Select Column On NS-1
Design
Material: Steel
Description: W 8 x 48
Weight: 48.0 plf
Modulus Of Elasticity: 29000 ksi
Moment Of Inertia: 184.0 in4
Cross Sectional Area: 14.1 in2
Number Of Shear Studs: 0
Use Copy Design
Select Column With Properties
Select All Other Columns Used For NS-1, NS-2, NS-3, EW-1, EW-2
Double Click Right Mouse Key To End Copying Designs


Define Properties
Select Upper Roof Horizontal Structural Plane
Beam Properties
Use Modify Design
Select Beam On NS-1
Design
Material: Steel
Description: W 12 x 22
Weight: 22.0 plf
Modulus Of Elasticity: 29000 ksi
Moment Of Inertia: 156.0 in4
Cross Sectional Area: 6.48 in2
Number Of Shear Studs: 0
Use Copy Design
Select Beam With Properties
Select All Other Beams Used For NS-1, NS-2, EW-1, EW-2
Double Click Right Mouse Key To End Copying Designs
Column Properties
Use Modify Design
Select Column On NS-1


Define Properties
Column Properties
Design
Material: Steel
Description: W 8 x 48
Weight: 48.0 plf
Modulus Of Elasticity: 29000 ksi
Moment Of Inertia: 184.0 in4
Cross Sectional Area: 14.1 in2
Number Of Shear Studs: 0
Use Copy Design
Select Column With Properties
Select All Other Columns Used For NS-1, NS-2, EW-1, EW 2
Double Click Right Mouse Key To End Copying Designs
Select Second Floor/ Lower Roof Horizontal Structural Plane
Lateral Analysis
Use Lateral Resistance Design
Select NS-1
Analysis
Units: Feet & Kips
Use Actual Properties
DL=Deck+Self Weight


Lateral Analysis
Connectivity
Hinge
Repeat For All Supports
Lateral Resistance Verify All Rigid Connections
Yes, Properties Are All Correct
Wind Load Options
Wind Direction: South
When 2 Wind Loads: Max. Suction
Wind Load: GCpi = 0
Flexible Diaphragm
Simple Beam Model
Rigid Horizontal Diaphragm Calculations
File Name: Rigidout.txt
Consider Perpendicular Wall...
View Loads
Analysis
Analysis File Name: Optional
Yes, The Loads & Connectivity Are Correct
View Shear, Moment, Deflection & Reaction Diagrams
View Output
Print Data
Rigid Diaphragm
All Other
Print To File
Execute Notepad


View Output
Scroll Output
Page Setup
Left Margin: 0.5 in
Right Margin: 0.0 in
Print File
Exit Notepad
End



Properties: w (plf), A (in2), E (ksi), I (in4)



1.00 Wind (klf) -- NS-1 -- F, 32%



1.00 Superimposed Dead (klf)



1.00 Dead (klf)



Total Combined Load -- Axial (k)



Total Combined Load -- Shear (k)



Total Combined Load -- Moment (kft)



Total Combined Load -- Deflection



Total Combined Load -- Loads & Reactions (k)

Project : Office Building - Scheme A
Location : Kadford AAP
Time : Wed Feb 26, 1992 3:56 PM

********** Rigid Horizontal Diaphragm Calculations **********

Center of Rigidity

Name	h (ft)	I (ft^4)	Av (ft^2)	Deflection (in)	Rigidity	R/ sum(R)	x (ft)	R*x
NS-1	14.0	0	0	0.101	9.917	32.48%	0.8	8.264
NS-2	14.0	0	0	0.101	9.917	32.48%	48.8	484.294
NS-3	14.0	0	0	0.093	10.697	35.04%	84.8	907.432
Sum					30.531			1399.991

Centroid from lower left = sum(R*x)/sum(R) : 45.85 ft
Maximum dimension : 85.67 ft
Eccentricity (e) = centroid-(max dimension)/2 : 3.02 ft
e min = 0.05*max. dimension : 4.28 ft
Eccentricity (e) used for torsional analysis : 3.02 ft
e min considered only for seismic analysis.

Name	h (ft)	I (ft^4)	Av (ft^2)	Deflection (in)	Rigidity	R/ sum(R)	x (ft)	R*x
EW-1	14.0	0	0	0.078	12.793	50.00%	72.8	931.750
EW-2	14.0	0	0	0.078	12.793	50.00%	0.8	10.661
Sum					25.586			942.411

Centroid from lower left = sum(R*x)/sum(R) : 36.83 ft
Maximum dimension : 73.67 ft
Eccentricity (e) = centroid-(max dimension)/2 : 0.00 ft
e min = 0.05*max. dimension : 3.68 ft
Eccentricity (e) used for torsional analysis : 0.00 ft
e min considered only for seismic analysis.

Assumptions used:
Deflections calculated by applying a 1 kip load.

Name	h (ft)	Rigidity	dx (ft)	R*dx	R*dx*dx	R*dx/ sum(R*dx*dx)
NS-1	14.0	9.917	45.0	446.487	20101.310	0.00641
NS-2	14.0	9.917	3.0	29.543	88.007	0.00042
NS-3	14.0	10.697	39.0	416.944	16252.029	0.00599
EW-1	14.0	12.793	36.0	460.545	16579.613	0.00662
EW-2	14.0	12.793	36.0	460.545	16579.613	0.00662
Sum					69600.573	

Shear distribution : Fv = V*R/sum(R)
Torsional moment : Mt = V*e
Torsional component : Ft = Mt*R*dx/sum(R*dx*dx)
Total shear to element: Ftotal = Fv + Ft

Seismic Loads




Calculate Seismic Loads
View Spectral Plots
Print Screen
Close Spectral Plots Dialog Window
Calculate
Review Plan Structural Irregularities
Review Vertical Structural Irregularities
Ct
Ct=0.035 For Steel Mom ent Resisting Frames
Beam Self Weight
Estimated Self Weight: 45 plf
Column Self Weight
Estimated Self Weight: 45 plf
Center Of Mass
File Name: Centmass.txt
Seismic
Yes, All The Loads Have Been Applied To The Structure And The Correct Load Combination Selected
View Output
Print Data
Seismic
Center Of Mass
All Other
Print To File
Execute Notepad


View Output
Scroll Output
Page Setup
Left Margin: 0.5 in
Right Margin: 0.0 in
Print File
Exit Notepad
End





Design Base Shear Coefficient Spectrum

```
Project      : Office Building - Scheme A
Location     : Radford AAP
Seismic Code: TM 5-809-10 1991
Time         : Sun Jan 26, 1992  1:40 PM

***************************** Seismic Analysis ******************************

 3. Upper Roof                              :    194.9 k
 2. Second Floor/Lower Roof                 :    686.9 k
-------------------------------------------------------
Total Building Weight (W)                   :    881.7 k

***************************** N - S and E - W *******************************

Zone: 2A: Z = 0.150
Importance Category: IV: I = 1.00
Soil Factor: S3: S = 1.5
System: C3a: Rw = 6
Ct = 0.035
hn = 28.0 ft
T = Ct*hn^3/4 = 0.43 sec
C = 1.25*S/T^2/3 = 3.29 > 2.75
C = 2.75
C/Rw = 0.458 > 0.075
W = 881.7 k
V = Z*I*C*W/Rw
+-----------------------+
|       V = 60.6 k      |
+-----------------------+

T < 0.7 sec
+-----------------------+
|       Ft = 0.0 k      |
+-----------------------+

+-----------------------+
|    V-Ft = 60.6 k      |
+-----------------------+
```

Level	h (ft)	Floor to Floor h (ft)	w (k)	sum(w) (k)	w*h (kft)	w*h/ sum(w*h)	F (k)	sum(F) V (k)
						Ft =	0.0	
3	28.0		195		5457	0.362	21.9	
		14.0		195				21.9
2	14.0		687		9616	0.638	38.7	
		14.0		882				60.6
1	0.0							
Sum			882		15073	1.000	60.6	

Level	h (ft)	Floor to Floor h (ft)	w (k)	sum(w) (k)	sum(F) V (k)	OTM (kft)	sum(OTM) (kft)	Ft+sum(F)/ sum(w)
3	28.0		195					
		14.0		195	21.9	307		0.113
2	14.0		687				307	
		14.0		882	60.6	849		0.069
1	0.0						1156	
Sum			882			1156		

Project : Office Building - Scheme A
Location : Radford AAP
Time : Sun Jan 26, 1992 1:40 PM

********** Center Of Mass **********

Upper Roof -- 28.00 ft

Name	Weight (k)	NS (ft)	NS*Weight (kft)	EW (ft)	EW*Weight (kft)
Exterior Wall	36.9	36.8	1358.9	0.8	30.7
Exterior Wall	24.6	0.8	20.5	24.8	610.8
Exterior Wall	36.9	36.8	1358.9	48.8	1801.6
Exterior Wall	24.6	72.8	1791.4	24.8	610.8
Upper Roof	49.8	36.8	1833.1	24.8	1235.9
Beam Self Weight	18.4	36.8	676.3	24.8	455.9
Column Self Weight	3.8	36.8	139.2	24.8	93.9
Sum	194.9		7178.2		4839.6

N-S Center Of Mass: 36.83 ft
E-W Center Of Mass: 24.83 ft

Second Floor/Lower Roof -- 14.00 ft

Name	Weight (k)	NS (ft)	NS*Weight (kft)	EW (ft)	EW*Weight (kft)
Second Floor	72.9	12.8	935.1	24.8	1809.5
Second Floor	60.7	36.8	2236.5	28.8	1750.8
Second Floor	72.9	60.8	4432.6	24.8	1809.5
Lower Roof	123.6	36.8	4554.0	66.8	8263.2
Exterior Wall	73.8	36.8	2717.8	0.8	61.5
Exterior Wall	24.6	0.8	20.5	24.8	610.8
Exterior Wall	36.9	36.8	1358.9	48.8	1801.6
Exterior Wall	24.6	72.8	1791.4	24.8	610.8
Parapet	9.9	0.8	8.3	66.8	662.1
Parapet	19.8	36.8	729.8	84.8	1680.9
Parapet	9.9	72.8	721.6	66.8	662.1
Beam Self Weight	24.8	36.8	914.9	36.2	899.9
Column Self Weight	5.7	36.8	208.8	36.2	205.4
Exterior Wall	43.0	0.8	35.9	42.8	1843.6
Exterior Wall	36.9	36.8	1358.9	84.8	3129.7
Exterior Wall	43.0	72.8	3134.9	42.8	1843.6
Column Self Weight	3.8	36.8	139.2	24.8	93.9
Sum	686.9		25299.0		27738.8

N-S Center Of Mass: 36.83 ft
E-W Center Of Mass: 40.39 ft

Seismic Lateral Analysis



Draw Upper Roof framing

Draw Surface In Bay A1-B2

Select Handle On Grid Line A1-A2

Select Handle On Grid Line B1-B2

Double Click Right Mouse Key To End Defining Area

Save Surface Element

Orientation: E-W



Copy Beams & One-Way Surface To Other Bays

Copy Structure

Select Third Point Beams

Select One-Way Surface

Double Click Right Mouse Key To End Selecting Structure

Select Grid Location A1 As The Base Point

Paste Structure

Select Grid Locations B1, A2, B2, A3, B3

Double Click Right Mouse Key To End




View Output
Scroll Output
Page Setup
Left Margin: 0.5 in
Right Margin: 0.0 in
Print File
Exit Notepad
End



Properties: w (plf), A (in2), E (ksi), I (in4)



1.00 Seismic (klf) -- NS-1 -- F, 32%



1.00 Superimposed Dead (klf)



1.00 Dead (klf)



Total Combined Load -- Axial (k)



Total Combined Load -- Shear (k)



Total Combined Load -- Moment (kft)



Total Combined Load -- Deflection



Total Combined Load -- Loads & Reactions (k)

Project : Office Building - Scheme A
Location : Radford AAP
Seismic Code: TM 5-809-10 1991
Time : Sun Jan 26, 1992 1:43 PM

********** Seismic Lateral Resistance Locations **********

NS-1 -- F, 32%

Level	h (ft)	Floor to Floor h (ft)	F (k)	sum(F) V (k)	OTM (kft)	sum(OTM) (kft)
3	28.0		21.9			
		14.0		21.9	307	
2	14.0		38.7			307
		14.0		60.6	849	
1	0.0					1156
Sum			60.6		1156	

NS-2 -- F, 32%

Level	h (ft)	Floor to Floor h (ft)	F (k)	sum(F) V (k)	OTM (kft)	sum(OTM) (kft)
3	28.0		21.9			
		14.0		21.9	307	
2	14.0		38.7			307
		14.0		60.6	849	
1	0.0					1156
Sum			60.6		1156	

NS-3 -- F, 35%

Level	h (ft)	Floor to Floor h (ft)	F (k)	sum(F) V (k)	OTM (kft)	sum(OTM) (kft)
2	14.0		38.7			
		14.0		38.7	541	
1	0.0					541
Sum			38.7		541	

Quantity Take-Off Philosophy

3 Considerations

1. One typical interior bay (exterior side bay, corner bay)



2. One typical floor level and roof level

3. The entire building structural system



Estimated weights are not used for quantity take-offs

Elements designed by Excel spreadsheets are used

Use Modify Design and Copy Design to manually enter element sizes

Calculated square footage can be overridden

Quantity Take-Off




Design All Elements To Include In Quantity Take-Off
Design Beam Elements
Select Third Point Beam With Properties
Select All Other Third Point Beams
Double Click Right Mouse Key To End Copying Designs
Use Copy Design
Select Girder With Properties
Select All Other Girders
Double Click Right Mouse Key To End Copying Designs
Design Column Elements
Use Copy Design
Select Interior Column With Properties
Select Other Interior Column
Double Click Right Mouse Key To End Copying Designs


Design All Elements To Include In Quantity Take-Off
Delete Designed Elements Not To Include In Take-Off
Use Modify Design
Select Beam C4-D4
Delete
Repeat For All Elements Supporting Lower Roof
Quantity Take-Off
Override Calculated Square Footage
NS: 72'
EW: 48'
View Output
Scroll Output
Page Setup
Left Margin: 0.5 in
Right Margin: 0.0 in
Print File
Exit Notepad
End

Project : Office Building - Scheme A
Location : Radford AAP
Time : Sun Jan 26, 1992 1:57 PM

********** Quantity Take-off **********

Second Floor/Lower Roof

Plan Area: 72.0 ft x 48.0 ft: 3456.0 sqft

STEEL: Narrowly Spaced Elements

Description	Length (ft)	Weight (plf)	Weight/ Element (lbs)	No.	Total Weight (lbs)
	24.0	0.0	0.0	24	0
Sum					0

Total Weight : 0.0 tons
Weight Per Square Foot : 0.0 psf

STEEL: Widely Spaced Elements

Description	Length (ft)	Weight (plf)	Weight/ Element (lbs)	No.	Total Weight (lbs)
W 14 x 48	24.0	48.0	1152.0	10	11520
	18.0	0.0	0.0	4	0
W 21 x 68	24.0	68.0	1632.0	4	6528
W 16 x 40	24.0	40.0	960.0	15	14400
	24.0	0.0	0.0	3	0
Sum					32448

Total Weight : 16.2 tons
Weight Per Square Foot : 9.4 psf

STEEL: Surface Elements

Description	Total Depth (in)	Area (sqft)	Weight (psf)	Conc Weight (pcf)	Conc Weight (psf)	Total Weight (lbs)	Conc (lbs)
Mtl Dk 2"-20ga/NLWT 2.5"	4.5	2880	2.0	145.0	42.0	5731	120960
Mtl Dk 2"-20ga/NLWT 2.5"	4.5	384	2.0	145.0	42.0	764	16128
	0.0	2592	0.0	0.0	0.0	0	0
Sum						6495	137088

Concrete Cubic Yards : 35.0
Total Weight : 3.2 tons

STEEL: Column Elements

Description	Length (ft)	Weight (plf)	Weight/ Element (lbs)	No.	Total Weight (lbs)
W 8 x 48	14.0	48.0	672.0	10	6720
W 8 x 28	14.0	28.0	392.0	2	784
	14.0	0.0	0.0	6	0
Sum					7504

Total Weight : 3.8 tons
Weight Per Square Foot : 2.2 psf

Concluding Remarks

Schemes A, B and C were developed to permit exploration and instruction of the broadest possible range of CASM capabilities. The schemes should not be viewed as completely logical structural framing solutions to the given design parameters, nor as necessarily economical. Each of the three schemes contain a variety of elements, which if properly combined and interchanged might produce "real" schemes for consideration at a 35% review.

Examples of unlikely components assembled in schemes A, B and C include: (1) concrete as a decking for the low roof, (2) custom made trusses for the low roof framing, (3) prefabricated limestone wall panels mixed with cast-in-place concrete shear walls, and (4) non-composite steel beam framing for the second floor.

A logical steel framed beam/column solution for "real" consideration would include open web steel joists spanning 48 feet for the upper roof to eliminate a central column in the second floor space. The lower roof would be framed with 36 foot span open web steel joists (without inclusion of custom trusses) as in scheme B. Both roofs would be sheathed with a metal roof deck without concrete and both would become flexible diaphragms. The second floor would be framed with composite steel beams as in scheme B and remain a rigid diaphragm. Two lateral load resistance system options could be compared. One scheme could include a moment resistant frame approach similar to scheme A, while a second approach might incorporate trussing similar to scheme B. The non-loadbearing exterior envelope is open to a variety of possibilities. The Architects will likely dictate the aesthetic expression. The foundation system would be a combination of isolated and linear spread footings.

A third logical solution would be a masonry bearing wall system to support the steel open-web joist roof planes described above. The second floor plane might be constructed of pre-cast pre-stressed hollow cored planks, which would also bear on the walls and a central steel girder line. Some of these walls could become shear walls for lateral load resistance. Thus the exterior envelope and the interior partition provide a structural function, eliminating costly moment connections and columns within the exterior wall layout. Footings are now all linear spread footings with only one isolated footing.

It is unlikely that a reinforced concrete frame would present an economical solution for a 1-2 story office building.

The structural engineers that become proficient with the use of CASM will be able to explore many other ideas to arrive at the most structurally efficient and economical solution for this hypothetical project.



Scheme 1: Moment connections for lateral load resistance

Scheme 2: Trussing for lateral load resistance





Scheme 3. Shear walls for lateral load resistance

8" CMU walls can be used as shear walls



REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

1. AGENCY USE ONLY *(Leave blank)*	2. REPORT DATE	3. REPORT TYPE AND DATES COVERED
	June 1992	Report 1 of a series

4. TITLE AND SUBTITLE
Concept Design Example, Computer Aided Structural Modeling (CASM); Report 1, Scheme A

5. FUNDING NUMBERS
Contract No.
DACA39-86-C-0024
Work Unit No. AT40-CA-001

6. AUTHOR(S)
David Wickersheimer, Gene McDermott, Carl Roth, Michael E. Pace

7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES)
Wickersheimer Engineers, Inc., 821 South Neil Street, Champaign, IL 61820; US Army Engineer Waterways Experiment Station, Information Technology Laboratory, 3909 Halls Ferry Road, Vicksburg, MS 39180-6199

8. PERFORMING ORGANIZATION REPORT NUMBER
Instruction Report ITL-92-3

9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)
US Army Corps of Engineers
Washington, DC 20314-1000

10. SPONSORING/MONITORING AGENCY REPORT NUMBER

11. SUPPLEMENTARY NOTES
Available from National Technical Information Service, 5285 Port Royal Road, Springfield, VA 22161.

12a. DISTRIBUTION/AVAILABILITY STATEMENT
Approved for public release; distribution is unlimited.

12b. DISTRIBUTION CODE

13. ABSTRACT *(Maximum 200 words)*

This is one in a series of three manuals designed to instruct in the use of the Computer Aided Structural Modeling (CASM) computer program. The manuals are composed of flowcharts which show step-by-step procedures for executing a broad range of CASM capabilities. CASM is a computer program designed to aid the structural engineer in the preliminary design and evaluation of structural building systems by the use of three-dimensional (3-D) interactive graphics. This manual contains one of three different framing schemes for the same 1-2 story office building. The examples contain a complete range of capabilities to permit framing comparisons, including 3-D geometry modeling, criteria specifications, development of loads (snow, wind, seismic, dead, and live), drawing structural elements, preliminary analysis and design of structural elements, and quantity take-offs.

14. SUBJECT TERMS
See reverse.

15. NUMBER OF PAGES
187

16. PRICE CODE

17. SECURITY CLASSIFICATION OF REPORT	18. SECURITY CLASSIFICATION OF THIS PAGE	19. SECURITY CLASSIFICATION OF ABSTRACT	20. LIMITATION OF ABSTRACT
UNCLASSIFIED	UNCLASSIFIED		

Waterways Experiment Station Cataloging-In-Publication Data

Concept design example, computer aided structural modeling (CASM) / by David Wickersheimer ... [et al] ; prepared for Department of the Army, US Army Corps of Engineers.

181 p. : ill. ; 28 cm. — (Instruction report ; ITL-92-3 rept. 1)

1. Structural frames — Computer simulation. 2. Computer-aided design. 3. Structural engineering — Computer programs. 4. Girders. I. Wickersheimer, David. II. United States. Army. Corps of Engineers. III. Computer-aided Structural Engineering Project. IV. U.S. Army Engineer Waterways Experiment Station. V. Series: Instruction report (U.S. Army Engineer Waterways Experiment Station) ; ITL-92-3 rept. 1.

TA7 W34i no.ITL-92-3 rept.1

WATERWAYS EXPERIMENT STATION REPORTS PUBLISHED UNDER THE COMPUTER-AIDED STRUCTURAL ENGINEERING (CASE) PROJECT

	Title	Date
Technical Report K-78-1	List of Computer Programs for Computer-Aided Structural Engineering	Feb 1978
Instruction Report O-79-2	User's Guide: Computer Program with Interactive Graphics for Analysis of Plane Frame Structures (CFRAME)	Mar 1979
Technical Report K-80-1	Survey of Bridge-Oriented Design Software	Jan 1980
Technical Report K-80-2	Evaluation of Computer Programs for the Design/Analysis of Highway and Railway Bridges	Jan 1980
Instruction Report K-80-1	User's Guide: Computer Program for Design/Review of Curvilinear Conduits/Culverts (CURCON)	Feb 1980
Instruction Report K-80-3	A Three-Dimensional Finite Element Data Edit Program	Mar 1980
Instruction Report K-80-4	A Three-Dimensional Stability Analysis/Design Program (3DSAD) Report 1: General Geometry Module Report 3: General Analysis Module (CGAM) Report 4: Special-Purpose Modules for Dams (CDAMS)	 Jun 1980 Jun 1982 Aug 1983
Instruction Report K-80-6	Basic User's Guide: Computer Program for Design and Analysis of Inverted-T Retaining Walls and Floodwalls (TWDA)	Dec 1980
Instruction Report K-80-7	User's Reference Manual: Computer Program for Design and Analysis of Inverted-T Retaining Walls and Floodwalls (TWDA)	Dec 1980
Technical Report K-80-4	Documentation of Finite Element Analyses Report 1: Longview Outlet Works Conduit Report 2: Anchored Wall Monolith, Bay Springs Lock	 Dec 1980 Dec 1980
Technical Report K-80-5	Basic Pile Group Behavior	Dec 1980
Instruction Report K-81-2	User's Guide: Computer Program for Design and Analysis of Sheet Pile Walls by Classical Methods (CSHTWAL) Report 1: Computational Processes Report 2: Interactive Graphics Options	 Feb 1981 Mar 1981
Instruction Report K-81-3	Validation Report: Computer Program for Design and Analysis of Inverted-T Retaining Walls and Floodwalls (TWDA)	Feb 1981
Instruction Report K-81-4	User's Guide: Computer Program for Design and Analysis of Cast-in-Place Tunnel Linings (NEWTUN)	Mar 1981
Instruction Report K-81-6	User's Guide: Computer Program for Optimum Nonlinear Dynamic Design of Reinforced Concrete Slabs Under Blast Loading (CBARCS)	Mar 1981
Instruction Report K-81-7	User's Guide: Computer Program for Design or Investigation of Orthogonal Culverts (CORTCUL)	Mar 1981
Instruction Report K-81-9	User's Guide: Computer Program for Three-Dimensional Analysis of Building Systems (CTABS80)	Aug 1981
Technical Report K-81-2	Theoretical Basis for CTABS80: A Computer Program for Three-Dimensional Analysis of Building Systems	Sep 1981
Instruction Report K-82-6	User's Guide: Computer Program for Analysis of Beam-Column Structures with Nonlinear Supports (CBEAMC)	Jun 1982

(Continued)

WATERWAYS EXPERIMENT STATION REPORTS PUBLISHED UNDER THE COMPUTER-AIDED STRUCTURAL ENGINEERING (CASE) PROJECT

(Continued)

	Title	Date
Instruction Report ITL-87-4	User's Guide: 2-D Frame Analysis Link Program (LINK2D)	Jun 1987
Technical Report ITL-87-4	Finite Element Studies of a Horizontally Framed Miter Gate Report 1: Initial and Refined Finite Element Models (Phases A, B, and C), Volumes I and II Report 2: Simplified Frame Model (Phase D) Report 3: Alternate Configuration Miter Gate Finite Element Studies–Open Section Report 4: Alternate Configuration Miter Gate Finite Element Studies–Closed Sections Report 5: Alternate Configuration Miter Gate Finite Element Studies–Additional Closed Sections Report 6: Elastic Buckling of Girders in Horizontally Framed Miter Gates Report 7: Application and Summary	Aug 1987
Instruction Report GL-87-1	User's Guide: UTEXAS2 Slope-Stability Package; Volume I, User's Manual	Aug 1987
Instruction Report ITL-87-5	Sliding Stability of Concrete Structures (CSLIDE)	Oct 1987
Instruction Report ITL-87-6	Criteria Specifications for and Validation of a Computer Program for the Design or Investigation of Horizontally Framed Miter Gates (CMITER)	Dec 1987
Technical Report ITL-87-8	Procedure for Static Analysis of Gravity Dams Using the Finite Element Method – Phase 1a	Jan 1988
Instruction Report ITL-88-1	User's Guide: Computer Program for Analysis of Planar Grid Structures (CGRID)	Feb 1988
Technical Report ITL-88-1	Development of Design Formulas for Ribbed Mat Foundations on Expansive Soils	Apr 1988
Technical Report ITL-88-2	User's Guide: Pile Group Graphics Display (CPGG) Post-processor to CPGA Program	Apr 1988
Instruction Report ITL-88-2	User's Guide for Design and Investigation of Horizontally Framed Miter Gates (CMITER)	Jun 1988
Instruction Report ITL-88-4	User's Guide for Revised Computer Program to Calculate Shear, Moment, and Thrust (CSMT)	Sep 1988
Instruction Report GL-87-1	User's Guide: UTEXAS2 Slope-Stability Package; Volume II, Theory	Feb 1989
Technical Report ITL-89-3	User's Guide: Pile Group Analysis (CPGA) Computer Group	Jul 1989
Technical Report ITL-89-4	CBASIN–Structural Design of Saint Anthony Falls Stilling Basins According to Corps of Engineers Criteria for Hydraulic Structures: Computer Program X0098	Aug 1989

(Continued)

WATERWAYS EXPERIMENT STATION REPORTS PUBLISHED UNDER THE COMPUTER-AIDED STRUCTURAL ENGINEERING (CASE) PROJECT

(Concluded)

	Title	Date
Technical Report ITL-89-5	CCHAN–Structural Design of Rectangular Channels According to Corps of Engineers Criteria for Hydraulic Structures: Computer Program X0097	Aug 1989
Technical Report ITL-89-6	The Response-Spectrum Dynamic Analysis of Gravity Dams Using the Finite Element Method; Phase II	Aug 1989
Contract Report ITL-89-1	State of the Art on Expert Systems Applications in Design, Construction, and Maintenance of Structures	Sep 1989
Instruction Report ITL-90-1	User's Guide: Computer Program for Design and Analysis of Sheet Pile Walls by Classical Methods (CWALSHT)	Feb 1990
Technical Report ITL-90-1	Investigation and Design of U-Frame Structures Using Program CUFRBC Volume A: Program Criteria and Documentation Volume B: User's Guide for Basins Volume C: User's Guide for Channels	May 1990
Instruction Report ITL-90-3	User's Guide: Computer Program for Two-Dimensional Analysis of U-Frame or W-Frame Structures (CWFRAM)	Sep 1990
Instruction Report ITL-90-2	User's Guide: Pile Group–Concrete Pile Analysis Program (CPGC) Preprocessors to CPGA Program	Jun 1990
Technical Report ITL-91-1	Application of Finite Element, Grid Generation, and Scientific Visualization Techniques to 2-D and 3-D Seepage and Groundwater Modeling	Sep 1990
Instruction Report ITL-91-1	User's Guide: Computer Program for Design and Analysis of Sheet-Pile Walls by Classical Methods (CWALSHT) Including Rowe's Moment Reduction	Oct 1991
Instruction Report ITL-87-2 (Revised)	User's Guide for Concrete Strength Investigation and Design (CASTR) in Accordance with ACI 318-89	Mar 1992
Technical Report ITL-92-2	Finite Element Modeling of Warped Thick Plates for Bonneville Navigation Lock	May 1992
Technical Report ITL-92-1	Introduction to the Computation of Response Spectrum for Earthquake Loading	Jun 1992
Instruction Report ITL-92-1	Concept Design Example, Computer Aided Structural Modeling (CASM) Report 1: Scheme A Report 2: Scheme B Report 3: Scheme C	 Jun 1992 Jun 1992 Jun 1992